

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. Contract Number	Page of Pages	
2. Amendment/Modification Number <b>DCAM-2007-B-0007-005</b>		3. Effective Date 12-Feb-07	4. Requisition/Purchase Request No.	1	2
6. Issued By: Office of Contracting and Procurement Construction, Design and Building Renovation Commodity Group 441 4th Street N.W., Suite 700 South Washington, D.C. 20001		Code 03B	7. Administered By (If other than line 6) Office of Contracting and Procurement 2000 14th Street, N.W., 3rd Floor Washington, D.C. 20009		
8. Name and Address of Contractor (No. Street, city, country, state and ZIP Code)			(X)	9A. Amendment of Solicitation No. <b>DCAM-2007-B-0007</b>	
				9B. Dated (See Item 11) 4-Dec-06	
				10A. Modification of Contract/Order No.	
Code			Facility	10B. Dated (See Item 13)	
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS					
<input type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended. <input checked="" type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning <u>2</u> copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or fax which includes a reference to the solicitation and amendment number. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or fax, provided each letter or telegram makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. Accounting and Appropriation Data (If Required)					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14					
(X)	A. This change order is issued pursuant to: (Specify Authority) The changes set forth in Item 14 are made in the contract/order no. in item 10A.				
	B. The above numbered contract/order is modified to reflect the administrative changes (such as changes in paying office, appropriation data, etc.) set forth in item 14, pursuant to the authority of 27 DCMR, Chapter 36, Section 3601.2.				
	C. This supplemental agreement is entered into pursuant to authority of:				
	D. Other (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input checked="" type="checkbox"/> is required to sign this document and return <u>2</u> copy to the issuing office.					
14. Description of amendment/modification (Organized by UCF Section headings, including solicitation/contract subject matter where feasible.)					
Attachment #1 - Response to request for clarifications					
The opening date for receipt of bids, time and place remains the same - February 15, 2007 by 2:00 p.m. local time.					
Except as provided herein, all terms and conditions of the document referenced in Item (9A or 10A) remain unchanged and in full force and effect					
15A. Name and Title of Signer (Type or print)			16A. Name of Contracting Officer <b>Diane Wooden</b>		
15B. Name of Contractor		15C. Date Signed	16B. District of Columbia	16C. Date Signed	
(Signature of person authorized to sign)				2/12/07	
			(Signature of Contracting Officer)		

Re: UDC – Building 52

The following is our response to FEI Construction Company's Request for Clarification #2 (email) dated 1/23/07.

1. Per previous response #15, existing granite wall panels will be required to be cleaned only, no refinishing.
2. There is no phasing in this project related to Owner's needs. Contractor is responsible for phasing of the demolition and construction of the work, keeping in mind any requirements for providing continuous utility service to the existing retail tenants. See general notes on dwg M112.
3. Fixtures type S1 & S1E, R2 & R2E are four feet long.

The following is our response to Compel Construction Inc.'s Request for Clarifications (fax) dated 1/15/07.

1. References to UL J502 on the Reflected Ceiling Plans should be deleted. The note should reference the code approved report number NER-258 for a horizontal shaftwall assembly.
2. The reference to UL design number NER-258 for a horizontal shaftwall system is incorrect. The reference is not a UL designation. It is a code approved report number (NER-258). The system has been tested for fire and is approved for use throughout the United States. The fire test number is WHI 495-PSH-0154/0167. Manufacturer's of shaftwall systems will have information on approved horizontal applications of their product. It is generally no different than vertical shaftwall assemblies except it will require suspension or bracing when exceeding its span capabilities.