AMENDMENT OF SOLICITATION / MODIFICATION OF CONTRACT	1. Contract Number	Page of Pages 1 3

2. Amendment/Modification Number	3. Effective Date	4. Requisition/Purchase Request No.	5. Solicitation Caption
DCAM-2007-B-0044-002	JUN 27 2007		Replacement and Repair of Exterior Limestone – Phase II at the D.C. National Guard Armory

6. Issued by: Code LRT	7. Administered by (If other than line 6)
Office of Contracting and Procurement Construction, Design and Building Renovation 441 4th Street, NW, Suite 700S Washington, DC 20001	Office of Contracting and Procurement Construction, Design and Building Renovation 441 4th Street, NW, Suite 700S Washington, DC 20001

8. Name and Address of Contractor (No. street, city, county, state and zip code)	9A. Amendment of Solicitation No. DCAM-2007-B-0044
	9B. Dated (See Item 11) May 15, 2007
	10A. Modification of Contract/Order No.
Code / DUNS: / TIN / FEIN:	10B. Dated (See Item 13)

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers ☒ is extended. ☐ is not extended. Offeror's must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning 2 copies of the amendment: (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) BY separate letter or fax which includes a reference to the solicitation and amendment number. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such may be made by letter or fax, provided each letter or telegram makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. Accounting and Appropriation Data (If Required) *To be cited on individual orders issued on behalf of participating agencies*

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14

X	A. This change order is issued pursuant to (Specify Authority): 27 DCMR, Chapter 36, Section 3603 The changes set forth in Item 14 are made in the contract/order no. in item 10A.
	B. The above numbered contract/order is modified to reflect the administrative changes (such as changes in paying office, appropriation data etc.) set forth in item 14, pursuant to the authority of
	C. This supplemental agreement is entered into pursuant to authority of:
	D. Other (Specify type of modification and authority)

E. IMPORTANT: Contractor ☐ is not ☒ is required to sign this document and return 2 copies to the issuing office.

14. Description of Amendment/Modification (Organized by UCF Section headings, including solicitation/contract subject matter where feasible

Pursuant to Article 3, Changes Clause of the General Provisions (Construction Contract), Government of the District of Columbia Standard Contract Provisions For Use With Specifications for District of Columbia Construction Projects 1973, the subject solicitation is hereby amended as follows:

1. The opening date for receipt of bids is scheduled for July 2, 2007 by 2:00 P.M. local time.

2. Listed below is the response to questions that was submitted to the Office of Contracting and Procurement in writing as Request for Information (RFI) 001 and RFI 002.

Except as provided herein, all terms and conditions of the document is referenced in Item 9A or 10A remain unchanged and in full force and effect.

15A. Name and Title of Signer (Type or print)		16A. Name of Contracting Officer Diane Wooden	
15B. Name of Contractor (Signature of person authorized to sign)	15C. Date Signed	16B. District of Columbia Diane Wooden (Signature of Contracting Officer)	16C. Date Signed 6/27/07

Contract Number	Amendment/Modification No.	Effective Date	Page of Pages
DCAM-2007-B-0044	DCAM-2007-B-0044-002	JUN 27 2007	2 of 3

14. Description of Amendment/Modification (Organized by UCF Section headings, including solicitation/contract subject matter where feasible).

Clarification to Question 2:

2. Demolition Note #1 on drawing CS.1 *"Repoint joints as required"*. It seems all of the existing mortar joints require repointing. Are we to assume all of the mortars are to be removed and replaced? If not, please specify a lineal foot quantity or percentage (i.e., 100%, 75% 50%, or etc.) of surface area of restoration to bid on.

Response to Clarification Question 2:

2. The quantity of the existing mortar joints shall be 50%.

Clarification to Question 3:

3. Specification section 07900 – Joint Sealer, part 1.2-B indicates installation of sealant at all windows and doors (interior and exterior). Please clarify the requirements (i.e., hours of work, relocation of furniture, etc.) for accessing the interior office space.

Response to Clarification Question 3:

3. The working hours are from 7:00 a.m. to 5:00 p.m.

Clarification to Question 4:

4. Specification section 04530 – Stone Masonry Restoration & Cleaning, part 2.3 – Cleaning Materials and Equipment refers to use D//2 Architectural Antimicrobial to clean the limestone. Please clarify if all of the limestone will be cleaned using D/2 Architectural Antimicrobial.

Response to Clarification Question 4:

4. All limestone shall be cleaned using D/2 Architectural Antimicrobial.

Clarification to Question 5:

5. Specification section 04530 – Stone Masonry Restoration & Cleaning, part 3.7 – Stone Consolidation Treatment. Where is this application to be used? Please clarify the location(s) for this treatment.

Response to Clarification Question 5:

5. The application shall be used as required in all areas.

Contract Number	Amendment/Modification No.	Effective Date	Page of Pages
DCAM-2007-B-0044	DCAM-2007-B-0044-002	JUN 27 2007	3 of 3

14. Description of Amendment/Modification (Organized by UCF Section headings, including solicitation/contract subject matter where feasible).

Clarification to Question 6:

6. What is the "Pounds Per Square Foot" loading restriction for the roof.

Response to Clarification Question 6:

6. The Contractor shall be responsible for any damages to the roof or the structure.

Clarification to Question 7:

7. There are aluminum ladders to be installed per bid drawings. Please provide appropriate specification section for this type work.

Response to Clarification Question 7:

7. The Contractor shall provide shop drawings for approval prior to installation.

Clarification to Question 8:

8. On drawing CS.1, Note 1 and 2 under demolition notes, appears as typical note for the entire phase 2 project. If this is the case, is there going to be a set unit price for each of t he notes? Or a percentage/quantity that will be applied to each note? Please revise and comment.

Response to Clarification Question 8:

8. 8% of the stone work shall be replaced.

Clarification to Question 9:

9. Is the water for the power wash be available at the site?

Response to Clarification Question 9:

9. Yes, water for the power wash is available at the site.