


| AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT   |   |                   | 1. Contract Number   | Page of Pages   |                  |
|--|---|-------------------|--|---|------------------|
| 2. Amendment/Modification Number   |   | 3. Effective Date | 4. Requisition/Purchase Request No.  | 5. Solicitation Caption                               |                  |
| DCAM-2007-B-0053-003   |   | 7-Mar-08          |  | Construction of New DOES Headquarters Building        |                  |
| 6. Issued By:<br>Office of Contracting and Procurement<br>Construction, Design and Building Renovation Group<br>441 4th street, NW, Suite 700 South<br>Washington, DC 20001  |   |                   | 7. Administered By (If other than line 6)  |   |                  |
| 8. Name and Address of Contractor (No. Street, city, country, state and ZIP Code)  |   |                   | (X)  | 9A. Amendment of Solicitation No.<br>DCAM-2007-B-0053 |                  |
|  |   |                   |  | 9B. Dated (See Item 11)<br>1/4/2008                   |                  |
|  |   |                   |  | 10A. Modification of Contract/Order No.               |                  |
|  |   |                   |  | 10B. Dated (See Item 13)                              |                  |
| Code   | Facility  |                   |  |   |                  |
| 11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS  |   |                   |  |   |                  |
| <input type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input checked="" type="checkbox"/> is extended. <input type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning <u>2</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or fax which includes a reference to the solicitation and amendment number. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or fax, provided each letter or telegram makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified. |   |                   |  |   |                  |
| 12. Accounting and Appropriation Data (If Required)  |   |                   |  |   |                  |
| 13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14  |   |                   |  |   |                  |
| A. This change order is issued pursuant to: (Specify Authority)  |   |                   |  |   |                  |
| The changes set forth in Item 14 are made in the contract/order no. in item 10A.   |   |                   |  |   |                  |
| B. The above numbered contract/order is modified to reflect the administrative changes (such as changes in paying office, appropriation date, etc.) set forth in item 14, pursuant to the authority of 27 DCMR, Chapter 36, Section 3601.2.  |   |                   |  |   |                  |
| (X)  | C. This supplemental agreement is entered into pursuant to authority of: 27 DCMR Sec 1517 |                   |  |   |                  |
| D. Other (Specify type of modification and authority)  |   |                   |  |   |                  |
| E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input checked="" type="checkbox"/> is required to sign this document and return <u>2</u> copies to the issuing office.  |   |                   |  |   |                  |
| 14. Description of amendment/modification (Organized by UCF Section headings, including solicitation/contract subject matter where feasible.)  |   |                   |  |   |                  |
| 1. The subject solicitation is hereby amended as follows:  |   |                   |  |   |                  |
| A. Response to bidder questions are included as Attachment A.  |   |                   |  |   |                  |
| B. The Revised Price Breakdown Form is included as Attachment B.   |   |                   |  |   |                  |
| C. Add revised Electrical, Plumbing and Mechanical drawings available for pick-up (free of charge) at the OCP, Bid Room located at 441 4th St., N.W. Suite 703 South, Washington, DC 20001.  |   |                   |  |   |                  |
| D. Add Table of Contents, Volume One dated October 30, 2007 is updated by Bulletin #1 dated February 19, 2008, available for pick-up at the above location.  |   |                   |  |   |                  |
| E. Add Geotechnical Report dated May 24, 2005, available for pick-up at the above location.  |   |                   |  |   |                  |
| Except as provided herein, all terms and conditions of the document referenced in Item (9A or 10A) remain unchanged and in full force and effect   |   |                   |  |   |                  |
| 15A. Name and Title of Signer (Type or print)  |   |                   | 16A. Name of Contracting Officer<br>Karen Hester                                     |   |                  |
| 15B. Name of Contractor  |   | 15C. Date Signed  | 16B. District of Columbia  |   | 16C. Date Signed |
| (Signature of person authorized to sign)   |   |                   |  |   | 3/9/08           |
|  |   |                   | (Signature of Contracting Officer)   |   |                  |

**AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT (Cont.)**

**SOLICITATION NO. DCAM-2007-B-0053-003**

- F. Section H, Paragraph H.1 – Change liquidated damages in the amount of \$20,730.34 per day and replace with \$3,000.00 per day.
- 2. All other terms and conditions remain unchanged.

**ATTACHMENT A**  
**SOLICITATION: DCAM-2007-B-0053**  
**Construction of New DOES Headquarters Building**

**RESPONSE TO OFFERORS QUESTIONS**

|   | IFB Section | Page # | Question  | Response  |
|---|-------------|--------|---|---|
| 1 |             |        | Please confirm that the Liquidated Damages for the DOES Building is \$20,730.34/day. We have heard from our bonding companies that the figure is very high.   | Liquidated Damages shall be \$3,000.00/day.   |
| 2 |             |        | Due to the fact that the project documents were not available to us until 2 days ago, please consider extending the question cut-off date by at least one week, to February 4 <sup>th</sup> . Also, please consider a two-week date extension with a bid submission time of 2:00 PM. A 10:00 AM bid submission is very problematic and does not allow enough time to properly process all subcontractor quotes.   | Bids must be received by 10:00 a.m. local time on March 31, 2008, as specified in Amendment No. DCAM-2007-B-0053-002 dated 2/22/08. |
| 3 |             |        | We ordered a set of specifications from national Reprographics. These specifications are dated October 30, 2007. The specifications we received from your office are dated February 23, 2007, Revised March 26, 2007. Which ones are we to use?   | The correct specification date is October 30, 2007.   |
| 4 |             |        | The bid time is 10:00 A.M. Friday, February 15, 2008. Can this time be changed to a more standard time such as 2:00 or 3:00 PM on a Tuesday, Wednesday or Thursday?   | No. See response to no. 2.  |
| 5 |             |        | <i>"The prospective bidders shall submit questions no later than 10 calendar days prior to the closing date and time indicated for this solicitation."</i> If the bid closing is February 15 <sup>th</sup> at 2:00 PM then the last questions should be able to submit questions until that deadline; no later than February 5 <sup>th</sup> at 2:00 PM. We respectful request that the question deadline remain as stated above to allow the bidding community time to review the documents more thoroughly. | The date for receipt of questions was extended to 2/29/08. See Amendment No. DCAM-2007-B-0053-002 dated 2/22/08.                    |

**ATTACHMENT A**  
**SOLICITATION: DCAM-2007-B-0053**  
**Construction of New DOES Headquarters Building**

**RESPONSE TO OFFERORS QUESTIONS**

|    | IFB Section | Page # | Question  | Response   |
|----|-------------|--------|---|--|
| 6  |             |        | The bid time is 10:00 A.M. Friday, February 15, 2008. Can this time be changed to a more standard time such as 2:00 or 3:00 PM on a Tuesday, Wednesday or Thursday?   | See response to no. 2.   |
| 7  |             |        | The solicitation Section H Special Requirements page 23 states that the liquidated damages are \$20,730.34 per calendar day. The project manual, Section 01100 Summary, Paragraph 1.8 C. states the liquidated damages are \$2,500 per calendar day. How are we to proceed?                       | Liquidated Damages shall be \$3,000.00/day   |
| 8  |             |        | Please correct and coordinate the drawing list in the (1) solicitation Part I, Section C.3, (2) the Index of Drawings on the cover sheet of each volume of drawings and (3) the actual drawings. Please correct the sheet and description to the actual drawings issued. None of the three agree. | This question will be answered in the next amendment.  |
| 9  |             |        | Phase 2 work is not part of this contract but will the telecommunications, data, security and furniture, fixture and equipment vendors and subcontractors be working at the same time as the Phase 1 contractors? If so please explain the scheduled overlap and expected level of interaction.   | There will be overlap between FF & E contractors and base building; the extent of which is yet to be determined. |
| 10 |             |        | Is landscaping part of the bid? Summary 01100 Paragraph 1.9.2 & 3 is blank. How are we to proceed?  | Landscaping is minimal and will be submitted as part of the civil package.                                       |
| 11 |             |        | The Specification Section 02469 - Aggregate Pier, requires the resumes and past experience of this specialty contractor to be submitted with the proposal. Can this requirement be waived until a general contractor is selected?   | Section 02469- Aggregate Pier Requirements shall not be waived and shall remain as a bid component.              |

**ATTACHMENT A**  
**SOLICITATION: DCAM-2007-B-0053**  
**Construction of New DOES Headquarters Building**

**RESPONSE TO OFFERORS QUESTIONS**

|    | IFB Section | Page # | Question  | Response  |
|----|-------------|--------|---|---|
| 12 |             |        | If shoring with tie-backs is required as mentioned in the documents has the Office of Property Management or construction manager obtained the necessary public easements in the public right-of-way and WMATA? Can the cost of such permits be included as an allowance in time and money since no contractor can determine this without further information?  | OPM has not obtained any Public Right of Way and WMATA easements with respect to tie backs for sheeting & shoring. Contractor shall assume an allowance for bidding purposes. |
| 13 |             |        | Can the authorities establish a PEPCO budget allowance for connection permits and fees for the permanent electrical work and services?  | Contractor shall include an allowance of \$50,000.00. See revised Price Breakdown Form  |
| 14 |             |        | Are we to provide bike racks shown on Detail 6/A-8.11 which are floor mounted loops or bike storage lockers? The floor plan and the detail do not agree. Can you provide the number of bikes to be stored and the type of locker to be used and storage configuration? How are we to proceed?   | Bicycle racks are now shown on sheet A2.3. Provide bicycle rack per detail 6/A8.11.   |
| 15 |             |        | We understand that new specification books are available and we have ordered copies but won't receive them until January 28 at the earliest. How can we ask questions before we review the new documents? There will be a lag time before the vendors and subcontractors get the new information too! Please extend the questions deadline and the bid date to allow the drawing and specifications to be reviewed. | See response to no. 2.  |
| 16 |             |        | Is the telecom and security portions to be bid separately since there was no description in the spec calling out the telecom or specifying the type of security equipment required.   | Contractor shall include an allowance of \$500,000.00. See revised Price Breakdown Form.  |

**ATTACHMENT A**  
**SOLICITATION: DCAM-2007-B-0053**  
**Construction of New DOES Headquarters Building**

**RESPONSE TO OFFERORS QUESTIONS**

|    | IFB Section         | Page # | Question   | Response  |
|----|---------------------|--------|--|---|
| 17 |                     |        | Due to the wrong specifications being given to Contractors, we are requesting an extension on submission of RFIs as well as a two week extension for the bid date  | See response to no. 2   |
| 18 |                     |        | What is the implication of 50% set-aside article. If we are LSDBE certified, are we still obligated to subcontract to an SBE only?   | Yes. See Section M.   |
| 19 | H.12-C Subcontracts |        | Please clarify the District's intent related to limitation of subcontracting work and/or the approval of subcontracts. Does the District intend to review the subcontract agreements and the actual subcontracts after the bid? What happens if the District rejects a subcontract and there are price implications to the contract? | OCP will not review Contractor Subcontract Agreements.  |
| 20 |                     |        | Due to the fact that the structural steel work is minimal, we are requesting that the AISC requirement be waived.  | No.   |
| 21 | General             |        | Details of the type of waterproofing system at the foundation are inadequate. Can the A/E provide details about the specified system?  | This question will be answered in the next amendment.   |
| 22 | 9-A4.10             |        | Aluminium/glass wall system is floating with no support system shown. Will the structural engineer provide details of the support system?  | Storefront verticals attach to underside of structural slab with clip angles as shown. Support steel for curtain wall or storefront framing is included in contract at no additional cost to Owner. |
| 23 | 14-A4.10            |        | The curtain wall parapet is shown as unsupported laterally. Will the A/E provide clarification related to the support system and/or kickers?   | This question will be answered in the next amendment.   |
| 24 | 6-5 3.2/6-A4.10     |        | The ornament precast closure beam is shown to be supported by the slab edge. This is a structural detail. Has the structural engineer signed performed the design and/or calculations for this detail? Can additional information be provided?   | This question will be answered in the next amendment.   |

**ATTACHMENT A**  
**SOLICITATION: DCAM-2007-B-0053**  
**Construction of New DOES Headquarters Building**

**RESPONSE TO OFFERORS QUESTIONS**

|    | IFB Section      | Page # | Question   | Response  |
|----|------------------|--------|--|---|
| 25 | 11-5 3.2/9-A4.10 |        | Embeds in the structural slab are not sized or detailed. The precaster will design embeds in the precast, however, the structural engineer has to provide details of embeds in the structural slabs. Can this information be provided to the bidders?    | All precast connections are the responsibility of contractor; see spec section 3450 – Architectural Precast Concrete. |
| 26 | 6&7 S3.2/S 1.7b  |        | P1 Columns are not located by dimensions or detailed on either the structural or architectural drawings. Can the A/E provide this information?   | See S.E. 2.3 & 2.4 Dwgs. As well as S.E. 2.1 thru 2.17 & A 0.3  |
| 27 | 6 S3.2/14 A4.10  |        | The details shows the entire beam being clad indirectly to the precast (No Framing). Since this is an architectural feature, can the A/E provide information on how to perform the connections for the precast cladding when the entire beam is covered? | This question will be answered in the next amendment.   |
| 28 | 8 S3.1           |        | Wall recess is not dimensioned. Can the A/E provide dimensions for this detail?  | Will show revised SE (Slab Edge) drawings in the next Amendment.  |
| 29 | A S3.1           |        | Top of wall recess is not dimensioned. Can the A/E provide dimensions for this detail?   | Will show revised SE (Slab Edge) drawings in the next Amendment.  |
| 30 | 6 S3.1           |        | Sheeting and Shoring is referenced on the documents as work by others. Can the A/E clarify that this work is in the contractors/bidders scope of work?   | Yes, Sheeting & Shoring is part of the contractors job. Refer to spec section 02250 – Shoring & Bracing.              |
| 31 |                  |        | Can you provide contractors/bidders a Geotechnical Report?   | The Geotechnical Report will be provided as part of this Amendment.   |
| 32 | Drawing PFBO.1   |        | Drawing shows thermostatic mixing valve TMV-1. Riser diagrams and floor plans do not show the location or quantity. Please advise.   | TMV-1 drawings to be revised in the next Amendment.   |
| 33 | PB2.4            |        | Note 3 calls out domestic hot water circulating pump. There does not seem to be a schedule for these circulating pumps nor a specific location. Please advise.   | Reference to domestic hot water circulating pump has been removed on dwg. PB2.4.                                      |

**ATTACHMENT A**  
**SOLICITATION: DCAM-2007-B-0053**  
**Construction of New DOES Headquarters Building**

**RESPONSE TO OFFERORS QUESTIONS**

|    | IFB Section | Page # | Question   | Response   |
|----|-------------|--------|--|--|
| 34 | 01572       |        | 01572-Construction Waste Managements-Included in specifications but not listed in Table of Contents. Is this spec to be included in our bid.   | Yes, section 1572 – Construction Waste Management should be included in contractor’s scope of work. See also spec section 1352-LEED Requirements.  |
| 35 | 15365       |        | 15365 is named in spec as “Fire Detection & FM-200 Fire Suppression System. Listed in Table of Contents as “Fire Detection and Halon Suppression System. Please verify which is correct. | Spec section 15365 should read “Fire Detection & FM-200 Fire Suppression System”. See revised Table of contents included as part of this Amendment.  |
| 36 | 15490       |        | 15490 is listed in Table of Contents but missing from specifications. Please provide.  | See Revised Table of Contents, Bulletin #1 dated 2/19/08, included as part of this Amendment.  |
| 37 | 15550       |        | 15550 is named in specifications as “Heat Exchanger & Fuel Oil Tanks”. Listed in Table of Contents as “Heat Generation & Fuel Oil Tanks.” Please verify which is correct.                | Spec section 15550 should read “Heat Exchanger Fuel Oil Tank”. See revised Table of Contents included as part of this Amendment.   |
| 38 | 15970       |        | 15970 is named in specs as “Building Control & Automatic Systems”. Listed in Table of Contents as “Direct Digital Control Systems. Please verify which is correct.                       | Spec section 15970 should read “Building Control & Automatic Systems”. See revised Table of Contents included as part of this Amendment.   |
| 39 | Drawing     |        | A1.1 through A1.3 – Drawing names and names in the List of Drawings do not match. Please verify.   | All documents shall be dated 10/30/07. These documents shall be inclusive of and referenced to Project Manual Volume I- (Division 1-14) dated October 30, 2007, Project Manual II – (Division 15 & 16) dated October 30, 2007, Bid Set – Volume 1 of 3, 2 of 3, 3 of 3 dated October 30, 2007 and Solicitation to Bid dated January 4, 2008. |
| 40 | Drawing     |        | A1.4 through A2.21 are included in the documents but not in the List of Drawings. Please clarify.  | See response to no. 39.  |

**ATTACHMENT A**  
**SOLICITATION: DCAM-2007-B-0053**  
**Construction of New DOES Headquarters Building**

**RESPONSE TO OFFERORS QUESTIONS**

|    | IFB Section | Page # | Question  | Response  |
|----|-------------|--------|---|---|
| 41 | Drawing     |        | A3.1 Drawing is named "South & East Elevations" but listed in the List of Drawings as "Minnesota Ave East Elevation". Please clarify.         | See response to no. 39.   |
| 42 | Drawing     |        | A3.2 Drawing is named "North & West Elevations" but named in the List of Drawings as "West Elevations". Please clarify.                       | See response to no. 39.   |
| 43 | Drawing     |        | A3.3 Drawing is named "Penthouse Elevations" but named in List of Drawings as "North and South Elevations". Please clarify.                   | See response to no. 39.   |
| 44 | Drawing     |        | A5.8 Drawing is named "Ceiling Details" but named in List of Drawings as "Plan Details". Please clarify.                                      | See response to no. 39.   |
| 45 | Drawing     |        | A6.7 Drawing is named "Stairs 7-14 Plans and Sections" but named in List of Drawings as "Stairs 7-12 Plans and Sections". Please clarify.     | A 6.7 drawing title should read: "Stairs 7-14". List of drawings to be revised in the next Amendment. |
| 46 | Drawing     |        | A6.8 Drawing is named "Stair Details" but named in the List of Drawings as "Garage Elevator Plans Sections and Cab Finishes". Please clarify. | See response to no. 39.   |
| 47 | Drawing     |        | A6.9 & A6.10 are included in the drawings but not in the List of Drawings. Are these drawings to be included in our bid?                      | See response to no. 39.   |

**ATTACHMENT A**  
**SOLICITATION: DCAM-2007-B-0053**  
**Construction of New DOES Headquarters Building**

**RESPONSE TO OFFERORS QUESTIONS**

|    | <b>IFB Section</b> | <b>Page #</b> | <b>Question</b>  | <b>Response</b>  |
|----|--------------------|---------------|--|--|
| 48 | Drawing            |               | A7.1 Drawing is named "Door Schedule, Elevations and Details" but named in the List of Drawings as "Door Schedule and Notes". Please clarify.        | SA 7.1 drawing title should read "Door Schedule, Elevations and Details." See revised drawings included as part of this Amendment. |
| 49 | Drawing            |               | A7.2 Drawing is named Door & Window Details but named in List of Drawings as Door Details. Please clarify.   | See response to no. 39.  |
| 50 | Drawing            |               | A7.9 through A7.11 Drawings are named "Curtainwall Elevations" but named in List of Drawings as "Window Elevations". Please clarify.                 | See response to no. 39.  |
| 51 | Drawing            |               | A7.12 Drawing is named as "Partition Types" but named in List of Drawings as "Finish Schedule & Notes". Please clarify.                              | See response to no. 39.  |
| 52 | Drawing            |               | A8.1 Named in drawings as "Finish Schedule" but not included in List of Drawings. Please clarify.  | See response to no. 39.  |
| 53 | Drawing            |               | A8.7 Named in drawings as "Lobby Details" but named in List of Documents as "Lobby Millwork Details". Please clarify.                                | See response to no. 39.  |
| 54 | Drawing            |               | SE2.1 through SE2.17 are not included in the List of Drawings. Please clarify.   | See response to no. 39.  |
| 55 | Drawing            |               | S1.1A and S1.1B Drawings are named "Partial Foundation Plan" but listed in List of Drawings as "Partial P2 Framing/Foundation Plan. Please clarify.  | See response to no. 39.  |
| 56 | Drawing            |               | S1.3A and S1.3B Drawings are named "Partial 1st Floor Plan" but named in List of Drawings as "Partial Ground Floor Plan". Please clarify.            | See response to no. 39.  |
| 57 | Drawing            |               | S1.5A and S1.5B Drawings are named "Partition Typical Floor Framing Plan" but named in List of Drawings as "Partial 3rd Floor Plan". Please clarify. | Drawing Index to be revised in the next Amendment.   |

**ATTACHMENT A**  
**SOLICITATION: DCAM-2007-B-0053**  
**Construction of New DOES Headquarters Building**

**RESPONSE TO OFFERORS QUESTIONS**

|    | IFB Section | Page # | Question   | Response   |
|----|-------------|--------|--|--|
| 58 | Drawing     |        | S4.1 Drawing is named "Stair Sections & Typical Details" but named in List of Drawings as "Stair Sections". Please clarify.  | Drawing Index to be revised in the next Amendment.   |
| 59 | Drawing     |        | All Mechanical, Electrical and Plumbing-Drawing numbers do not match drawing numbers in List of Drawings. Please clarify.  | See response to no. 39.  |
| 60 | Drawing     |        | I2.21 Drawing is named as "Restroom Plans" but named in List of Drawings as "Enlarged Toilet Plans". Please clarify.   | Cover sheet to be revised in the next Amendment.   |
| 61 | Drawing     |        | I5.1 Ceiling Details is not included in The List of Drawings. Please clarify.  | See response to no. 39.  |
| 62 | Drawing     |        | I8.2 through I9.10 is not included in the List of Drawings. Please clarify.  | See response to no. 39.  |
| 63 | Drawing     |        | MT, PT and ET drawings are not included in the List of Drawings. Please clarify.   | See response to no. 39.  |
| 64 | Division 16 |        | Div 16 calls for empty ¾" conduit with pull string for telephone to be run from each outlet back to the Telephone Room. Is this correct? Normal practice is to run conduit with pull string up to the plenum and then run plenum rated cable in a trough back to the Telephone Room. | No, run conduit with pull string up to the plenum and then plenum rated cables in trough back to the Telephone Room. |
| 65 | Drawing     |        | Plumbing fixture schedule on the Tenant Drawings does not jive with the fixture call outs on the drawings. There is no specification for the kitchen sinks and water fill stations. Please advise.   | Plumbing fixture schedule and drawings to be coordinated. Sink & water fill station to be provided.                  |
| 66 | Drawing     |        | Door 123A (Base Building Volume 1, Sheet A7.1) is indicated as a Type 15 door which is a double door type, but the size shown on the schedule reflects a single door. Is this intended to be a Type 16 door?   | Door 123A should be type 16. Door schedule to be revised in the next Amendment.                                      |

**ATTACHMENT A**  
**SOLICITATION: DCAM-2007-B-0053**  
**Construction of New DOES Headquarters Building**

**RESPONSE TO OFFERORS QUESTIONS**

|    | IFB Section | Page # | Question   | Response   |
|----|-------------|--------|--|--|
| 67 | Drawing     |        | Door 130 B (Base Building Volume 1, Sheet A7.1) is indicated as a Type 18 door which is a single door type, but the size shown on the schedule reflects a double door. Is this intended to be a Type 19 door?  | No, Door 130B should be type 14 door. Door schedule to be revised in the next Amendment. |
| 68 | Drawing     |        | Several interior elevations indicated "Polyvision 5'x8' Whiteboard Edge Series", but the board shown graphically measures 5'x6' (See Details 10/18.22, 3/18.26, 9/18.26, 8/18.28). Other interior elevations reflecting this note and whiteboard do indeed measure this size. Please clarify.  | All boards to be "Polyvision 5' x 8' Whiteboard Edge Series"                             |
| 69 |             |        | The documents included in the solicitation are titled "Bid Set". They are not stamped by the architects or any of the design engineers and there are many missing dimensions which will not allow construction until resolved. Is there going to be a stamped "For Construction" document set issued? If so, when? We need this information to evaluate professional staffing needs and schedule requirements. | See response to no. 39.  |

ATTACHMENT B

**B.6 PRICE BREAKDOWN FORM (Revised March 7, 2008)**

The bidder must complete this breakdown of prices and submit it with its bid. In case of any discrepancy in the total bid price entered here, the lump sum price in Section-B.5 shall govern.

Breakdown into Divisions of lump sum price bid under CLIN 0001, Section-B.5

| DIVISION NO. *            | DESCRIPTION  | TOTAL PRICE BREAKDOWN                 |
|---------------------------|--|---------------------------------------|
| Div. 01                   | General Requirements<br><b>PEPCO Allowance</b>                       | \$ _____<br><b>\$50,000.00</b> .....  |
| Div. 02                   | Site Construction  | .....                                 |
| Div. 03                   | Concrete   | .....                                 |
| Div. 04                   | Masonry  | .....                                 |
| Div. 05                   | Metals   | .....                                 |
| Div. 06                   | Wood and Plastics  | .....                                 |
| Div. 07                   | Thermal and Moisture Protection                                      | .....                                 |
| Div. 08                   | Doors and Windows  | .....                                 |
| Div. 09                   | Finishes   | .....                                 |
| Div. 10                   | Specialties  | .....                                 |
| Div. 11                   | Equipment  | .....                                 |
| Div. 12                   | Furnishings  | .....                                 |
| Div. 13                   | Special Construction (Intentionally Left Blank)                      |                                       |
| Div. 14                   | Conveying Systems  | .....                                 |
| Div. 15                   | Mechanical   | .....                                 |
| Div. 16                   | Electrical & Communication<br><b>Telecom and Security Allowance</b>  | \$ _____<br><b>\$500,000.00</b> ..... |
| Div. 17                   | Commissioning  |                                       |
| <b>Lump Sum Bid Price</b> | Lump Sum Bid Price (copy from CLIN 0001, Section-B.5, Part-I of IFB) | .....                                 |

- DIVISION means a discrete component of the work for which a separate price is requested. The “Total Price Breakdown” is the sum total of all components, and must equal the Lump Sum Bid Price. If there is any discrepancy in the total bid price entered here and the lump sum price in B.5, Section-B.5 shall govern.