AMENDMENT OF SOLICITATION / MODIFICATION OF CONTRACT

1. Contract Number	Page of Pages	
	1	2

2. Amendment/Modification Number	3. Effective Date	4. Requisition/Purchase Request No.	5. Solicitation Caption
DCAM-2007-B-0104-003	November 7, 2007		Doors and Windows Replacement at Emery Shelter

6. Issued by: Code LRT	7. Administered by (If other than line 6)
Office of Contracting and Procurement Construction, Design and Building Renovation 441 4th Street, NW, Suite 700S Washington, DC 20001	Office of Contracting and Procurement Construction, Design and Building Renovation 441 4th Street, NW, Suite 700S Washington, DC 20001

8. Name and Address of Contractor (No. street, city, county, state and zip code)	9A. Amendment of Solicitation No.
	DCAM-2007-B-0104
	9B. Dated (See Item 11)
	August 16, 2007
	10A. Modification of Contract/Order No.
Code / DUNS: / TIN / FEIN:	10B. Dated (See Item 13)

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers ☐ is extended. ☒ is not extended. Offeror's must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning 2 copies of the amendment: (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) BY separate letter or fax which includes a reference to the solicitation and amendment number. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such may be made by letter or fax, provided each letter or telegram makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. Accounting and Appropriation Data (If Required) *To be cited on individual orders issued on behalf of participating agencies*

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14

X	A. This change order is issued pursuant to (Specify Authority): 27 DCMR, Chapter 36, Section 3603 The changes set forth in Item 14 are made in the contract/order no. in item 10A.
	B. The above numbered contract/order is modified to reflect the administrative changes (such as changes in paying office, appropriation data etc.) set forth in item 14, pursuant to the authority of
	C. This supplemental agreement is entered into pursuant to authority of:
	D. Other (Specify type of modification and authority)

E. IMPORTANT: Contractor ☐ is not ☒ is required to sign this document and return 2 copies to the issuing office.

14. Description of Amendment/Modification (Organized by UCF Section headings, including solicitation/contract subject matter where feasible

Pursuant to Article 3, Changes Clause of the General Provisions (Construction Contract), Government of the District of Columbia Standard Contract Provisions For Use With Specifications for District of Columbia Construction Projects 1973, the subject solicitation is hereby amended as follows:

1. Listed below is the response to questions that was submitted to the Office of Contracting and Procurement.

Except as provided herein, all terms and conditions of the document is referenced in Item 9A or 10A remain unchanged and in full force and effect.

15A. Name and Title of Signer (Type or print)		16A. Name of Contracting Officer Diane Wooden	
15B. Name of Contractor (Signature of person authorized to sign)	15C. Date Signed	16B. District of Columbia Diane Wooden (Signature of Contracting Officer)	16C. Date Signed 11/7/07

14. Description of Amendment/Modification (Organized by UCF Section headings, including solicitation/contract subject matter where feasible).

Question 1:

1. It appears there is lead abatement wanted on many areas if the building, inside and out, that are not connected to the window replacements, if we are looking at everything listed on Tables 1 and 2. Is this correct?
2. Is there painting to be done on those areas after the lead abatement is completed? If so we don't see it on the solicitation?

Response 1:

1. The lead abatement report and specifications are intended to inform the bidder where lead paint has been identified and to take the appropriate measures in executing the contract. It is not intended that all lead identified be abated, only that which affects the execution of the contract. All areas that are affected by the abatement shall be restored.

2. The existing windows and doors are to be removed leaving only the masonry openings. This means that all replacements (doors, windows and trim) should be new and painted to match existing.