

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. Contract Number	Page of Pages 1 1	
2. Amendment/Modification Number DCAM-2008-B-0089-003		3. Effective Date 16-Jul-08	4. Requisition/Purchase Request No.	5. Solicitation Caption Classroom Renov, Rm A04 Bldg 46W	
6. Issued By: Office of Contracting and Procurement Construction, Design and Building Renovation 441 4th Street, NW, Suite 700 South Washington, DC 20001			Code	7. Administered By (If other than line 6) Office of Property Management 2000 14th Street, N.W. Washington, DC 20009	
8. Name and Address of Contractor (No. Street, city, country, state and ZIP Code)			(X)	9A. Amendment of Solicitation No. DCAM-2008-B-0089-003	
				9B. Dated (See Item 11) 16-Jul-08	
				10A. Modification of Contract/Order No.	
				10B. Dated (See Item 13)	
Code	Facility				
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS					
<input type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input checked="" type="checkbox"/> is extended. <input type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or fax which includes a reference to the solicitation and amendment number. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or fax, provided each letter or telegram makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. Accounting and Appropriation Data (If Required)					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14					
(X)	A. This change order is issued pursuant to: (Specify Authority) The changes set forth in Item 14 are made in the contract/order no. in item 10A.				
	B. The above numbered contract/order is modified to reflect the administrative changes (such as changes in paying office, appropriation date, etc.) set forth in item 14, pursuant to the authority of 27 DCMR, Chapter 36, Section 3601.2.				
	C. This supplemental agreement is entered into pursuant to authority of:				
	D. Other (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input checked="" type="checkbox"/> is required to sign this document and return <u>1</u> copies to the issuing office.					
14. Description of amendment/modification (Organized by UCF Section headings, including solicitation/contract subject matter where feasible.)					
Solicitation No. DCAM-2008-B-0089 is hereby amended as follows:					
(1). Questions and Answers attached.					
(2). The subject Bid Opening date is hereby extended from Thursday, July 17, 2008, at 2:00 pm, local time to Friday, July 25, 2008, at 2:00 pm, local time.					
(3). Additional questions and answers are forthcoming.					
(4). All other terms and conditions remain the same.					
Except as provided herein, all terms and conditions of the document referenced in Item (9A or 10A) remain unchanged and in full force and effect					
15A. Name and Title of Signer (Type or print)			16A. Name of Contracting Officer Diane Wooden		
15B. Name of Contractor		15C. Date Signed	16B. District of Columbia		16C. Date Signed
(Signature of person authorized to sign)			<i>Diane Wooden</i> (Signature of Contracting Officer)		7/16/08

Classroom Renovations, Room A04, Building 46W

DCAM-2008-B-0089 Questions and Answers

- (1). **Q:** What is the Solicitation Number?
A: DCAM-2008-B-0089
- (2). **Q:** Are DCADA Standards Applicable to this project, i.e., fire alarm, exits signs, ramps, etc?
A: Yes
- (3). **Q:** Will the UDC provide Contractor ID and access such keys or codes?
A: The staff at UDC will coordinate access to the building with contractor after contract award. .
- (4). **Q:** Has this requirement been for bid previously? If so, what happened? What Changed?
A: No
- (5). **Q:** When do you anticipate Notice to Proceed (NTP)
A: We anticipate award within 15 days after Bid Opening. The NTP will be issued immediately following the Pre-Construction Meeting.
- (6). **Q:** Do we need a Bid Bond? If so, what percentage will be required?
A: The project requires a 5% Bid Bond.
- (7). **Q:** Please provide your email address.
A: Sherry.Quashie@dc.gov.
- (8). **Q:** How many stories are there?
A: 1 story
- (9). **Q:** What is the property value for the purpose of Builders Risk Insurance?
A: Builders Risk Insurance should be in the amount of the bid.

- (10). **Q:** What year was the structure built?
A: 1971
- (11). **Q:** Ref: Drawing A1.2 Detail B, Note 3;
Detail B, Note 3 states to install LED wall washer light fixture to a 1½” Pole. Please specify type of pole.
A: GC to coordinate new location with UDC.
- (12). **Q:** Ref: Drawing A1.2 Detail B, Note 3
Detail B, Note 3 states to install LED wall washer light fixture to a 1½” pole. Please specify type of pole.
A: Provide schedule 40 steel type.
- (13). **Q:** Ref: Drawing 46W-E-2 Type D Lighting Fixture Manufacturer;
Lighting Fixture Schedule Type D LED wall washer light fixture
Manufacturer: Wiedamark has no Model/Cat#. Please provide.
A: LED Color changing Par 64 fixture.
- (14). **Q:** Ref: Drawing AV.01 Riser Diagram;
Riser Diagram shows a “trough” (long narrow junction box) to be installed. The drawing does not indicate size to install. Please clarify
A: Size trough as required to accommodate wiring.
- (15). **Q:** Ref: Specification Section 10101 Visual Display Surfaces;
Drawings does not show location to install a Marker board. Is it the intention of the owner to install a Marker board? Please indicate exact location.
A: There is no Visual Display Surface or Markerboard.
- (16). **Q:** Do we need to provide the auditorium seats?
A: Yes
- (17). **Q:** Do we provide the auditorium seats with electrical recepticles? (The electrical drawings do not show the location and installation for these devices)
A: Yes

18). Q: Is it possible to have a walk-through?

A: A walk-through was conducted at the Pre-bid conference.