

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. Contract Number	Page of Pages 1 1	
2. Amendment/Modification Number DCAM-2008-R-0088-005		3. Effective Date 5-Nov-08	4. Requisition/Purchase Request No.	5. Solicitation Caption Consolidated Forensics Laboratory	
6. Issued By: Office of Contracting and Procurement Construction, Design and Building Renovation 441 4th Street, NW, Suite 700 South Washington, DC 20001		Code	7. Administered By (If other than line 6) Office of Property Management 2000 14th Street, N.W. Washington, DC 20009		
8. Name and Address of Contractor (No. Street, city, country, state and ZIP Code)			(X)	9A. Amendment of Solicitation No. DCAM-2008-R-0088	
				9B. Dated (See Item 11) 25-Sep-08	
				10A. Modification of Contract/Order No.	
				10B. Dated (See Item 13)	
Code	Facility				
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS					
<input type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended. <input checked="" type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or fax which includes a reference to the solicitation and amendment number. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or fax, provided each letter or telegram makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. Accounting and Appropriation Data (If Required)					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14					
(X)	A. This change order is issued pursuant to: (Specify Authority) The changes set forth in Item 14 are made in the contract/order no. in item 10A.				
	B. The above numbered contract/order is modified to reflect the administrative changes (such as changes in paying office, appropriation date, etc.) set forth in item 14, pursuant to the authority of 27 DCMR, Chapter 36, Section 3601.2.				
	C. This supplemental agreement is entered into pursuant to authority of:				
	D. Other (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input checked="" type="checkbox"/> is required to sign this document and return <u>1</u> copies to the issuing office.					
14. Description of amendment/modification (Organized by UCF Section headings, including solicitation/contract subject matter where feasible.) Solicitation No. DCAM-2008-R-0088, is hereby amended as follows: (1). Section L.28, Delete COB, November 7, 2008, and replace with COB November 12, 2008. (2). Additional Questions and Answers, (Attachment A). (3). Revised drawings and specification list, (Attachment B). (4). MPD 1-D Condition Assessment Report, (Attachment C). (5). All other terms and conditions remain the same.					
Except as provided herein, all terms and conditions of the document referenced in Item (9A or 10A) remain unchanged and in full force and effect					
15A. Name and Title of Signer (Type or print)			16A. Name of Contracting Officer Diane Wooden		
15B. Name of Contractor (Signature of person authorized to sign)		15C. Date Signed	16B. District of Columbia <i>Diane Wooden</i> (Signature of Contracting Officer)		16C. Date Signed 11/5/08

Attachment A

ANSWERS TO OFFERORS QUESTIONS

Quest. No.	Question	Answer																																														
53.	<p>Reference: Section 089250 & 086310</p> <p>a. The specification is calling for laminated glass and on the drawings A-511 & A-512E indicate GL04 as insulated fritted glass. What is the correct glass? What are the required glass performances (U value, shading coefficient,...)? If the glass is fritted then, what is the intended frit pattern?</p> <p>b. Specification 089250 – page 19 is calling for fittings to be countersunk, no exterior caps, plates or fittings and the architectural drawings A-733 detail 3 show patch fitting cover 16"X8.8". What is the correct fitting?</p> <p>c. We need more information regarding the seismic. What is the inelastic lateral drift measured in the plane of glass for the point supported glass?</p>	<p>a. GL04 is insulated fritted glass described on A511. The glass and its performance shall match the below criteria; it is a 50% frit. The frit pattern is shown on 2 A733.</p> <table border="1" data-bbox="1024 435 1812 1141"> <thead> <tr> <th data-bbox="1024 435 1463 467">Product</th> <th data-bbox="1467 435 1812 467">VE 1-2M</th> </tr> </thead> <tbody> <tr> <td colspan="2" data-bbox="1024 469 1812 501">Transmittance</td> </tr> <tr> <td data-bbox="1024 503 1463 535">Visible Light</td> <td data-bbox="1467 503 1812 535">44%</td> </tr> <tr> <td data-bbox="1024 537 1463 570">Solar Energy</td> <td data-bbox="1467 537 1812 570">20%</td> </tr> <tr> <td data-bbox="1024 571 1463 604">Ultra-Violet*</td> <td data-bbox="1467 571 1812 604">5%</td> </tr> <tr> <td colspan="2" data-bbox="1024 605 1812 638">Reflectance</td> </tr> <tr> <td data-bbox="1024 639 1463 672">Visible Light-Exterior</td> <td data-bbox="1467 639 1812 672">22%</td> </tr> <tr> <td data-bbox="1024 673 1463 706">Visible Light-Interior</td> <td data-bbox="1467 673 1812 706">26%</td> </tr> <tr> <td data-bbox="1024 708 1463 740">Solar Energy</td> <td data-bbox="1467 708 1812 740">29%</td> </tr> <tr> <td colspan="2" data-bbox="1024 742 1812 774">ASHRAE U-Value</td> </tr> <tr> <td data-bbox="1024 776 1463 808">Winter Nighttime</td> <td data-bbox="1467 776 1812 808">0.29 Btu/(hr x sqft x °F)</td> </tr> <tr> <td data-bbox="1024 810 1463 842">Summer Daytime</td> <td data-bbox="1467 810 1812 842">0.26 Btu/(hr x sqft x °F)</td> </tr> <tr> <td colspan="2" data-bbox="1024 844 1812 876">European U-Value</td> </tr> <tr> <td data-bbox="1024 878 1463 911"></td> <td data-bbox="1467 878 1812 911">1.5</td> </tr> <tr> <td colspan="2" data-bbox="1024 912 1812 945">Shading Coefficient</td> </tr> <tr> <td data-bbox="1024 946 1463 979"></td> <td data-bbox="1467 946 1812 979">0.30</td> </tr> <tr> <td colspan="2" data-bbox="1024 980 1812 1013">Relative Heat Gain</td> </tr> <tr> <td data-bbox="1024 1015 1463 1047"></td> <td data-bbox="1467 1015 1812 1047">63 Btu/hr x sqft</td> </tr> <tr> <td colspan="2" data-bbox="1024 1049 1812 1081">Solar Factor (SHGC)</td> </tr> <tr> <td data-bbox="1024 1083 1463 1115"></td> <td data-bbox="1467 1083 1812 1115">0.26</td> </tr> <tr> <td colspan="2" data-bbox="1024 1117 1812 1149">LSG</td> </tr> <tr> <td data-bbox="1024 1151 1463 1183"></td> <td data-bbox="1467 1151 1812 1183">1.69</td> </tr> <tr> <td colspan="2" data-bbox="1024 1185 1812 1218">* Ultra-violet defined as 300 to 380 nanometers (nm)</td> </tr> </tbody> </table> <p>b. The atrium glass wall design is a patch plate wall system. The reference to countersunk in the specification is to address any event where a patch plate system may incorporate bolting thru the glass. There are various Patch plate systems available in the market place and some of the designs incorporate holes in the glass, which is all this is addressing.</p> <p>c. The inelastic lateral drift is actually controlled by the wind induced drift. Per code this is limited to ½ inch per floor height, with the atrium wall spanning across 6 floors the maximum drift in the overall height of the wall would be limited to 3 inches.</p>	Product	VE 1-2M	Transmittance		Visible Light	44%	Solar Energy	20%	Ultra-Violet*	5%	Reflectance		Visible Light-Exterior	22%	Visible Light-Interior	26%	Solar Energy	29%	ASHRAE U-Value		Winter Nighttime	0.29 Btu/(hr x sqft x °F)	Summer Daytime	0.26 Btu/(hr x sqft x °F)	European U-Value			1.5	Shading Coefficient			0.30	Relative Heat Gain			63 Btu/hr x sqft	Solar Factor (SHGC)			0.26	LSG			1.69	* Ultra-violet defined as 300 to 380 nanometers (nm)	
Product	VE 1-2M																																															
Transmittance																																																
Visible Light	44%																																															
Solar Energy	20%																																															
Ultra-Violet*	5%																																															
Reflectance																																																
Visible Light-Exterior	22%																																															
Visible Light-Interior	26%																																															
Solar Energy	29%																																															
ASHRAE U-Value																																																
Winter Nighttime	0.29 Btu/(hr x sqft x °F)																																															
Summer Daytime	0.26 Btu/(hr x sqft x °F)																																															
European U-Value																																																
	1.5																																															
Shading Coefficient																																																
	0.30																																															
Relative Heat Gain																																																
	63 Btu/hr x sqft																																															
Solar Factor (SHGC)																																																
	0.26																																															
LSG																																																
	1.69																																															
* Ultra-violet defined as 300 to 380 nanometers (nm)																																																

ANSWERS TO OFFERORS QUESTIONS

54.	Reference: Amendment 04, Question 48: Please define "all material punchlist items" provided under the new provided definition for "Substantial Completion"	Material punchlist items are defined as major punchlist items that when completed a) will allow completion of the commissioning process; b) will allow obtaining certificate of occupancy for the building, and c) will allow the District to use the space for its intended purposes. This does not necessarily means 100% of all punchlist items. Please refer to question #48 in Amendment 04.
55.	Reference: Electrical Branch conduits in the slabs Drawing S001, note J16 indicates, in slab conduits are acceptable, however Spec 260519 paragraph 3.2J states "not permitted". The slab thickness for the B-2 level is 42" and for B-1 it is 9-1/2" thick, and the other levels are 10-1/2" thick. Will PVC in the slabs be permitted that comply with Note J16 on Drawing S001.	Electrical conduits will only be allowed in B-2 level (42" Mat slab). No conduits will be allowed in any other Floor slab. Note J16 on Dwg. S001 shall be revised accordingly.
56.	Reference: Electrical MC Cable Specification section 260519 para 3.2H allows the use of MC cable for branch circuits in concealed locations, however spec. section 260533 para. 1B3 indicates to use EMT in concealed areas. Drawing E804 detailE indicates EMT installed between banks of lights with MC cable connecting individual lights. Please provide a clarification for the use of MC cable for both lighting and branch power devices and equipment in concealed dry areas.	260519.3.2.H does allow THHN-THWN conductors in raceway (EMT), MC cable or MI cable for concealed "branch circuits". Contractors need to refer to 260519.1.3 for the definition of feeders versus branch circuit. Please note that 260519.3.2.H does not allow MC cable for "equipment". 260533.3.1.B.3 also allows conductors in EMT, concealed in ceilings, walls and partitions. Therefore either method complies and is acceptable. Either installation method must also comply with Electrical code and local supplements per 260519.1.5. and 260533.1.5.
57.	Please note questions below from demolition subcontractors. We discussed at the pre-bid meeting having access to the as-built drawings. General answers/proportions instead of exact locations should be fine. 1. What is the frame of the building: concrete CIP/Post tension or steel frame? 2. What is the column spacing of the building? 3. What kind slabs make up the floor (splayed joist/ waffle pan) and what is the slab thickness of the floors and are there any abnormal floors that are thicker than others?	Additional information is provided on MPD 1-D building as part of this Amendment (see Attachment "C" - "Condition Building Assessment" report, dated 8/31/2005). This is a comprehensive survey of the building site, structure, interior, envelope and systems. Demolition work is scheduled to start immediately after issuing NTP and after the GC obtains all required permits, including Raze permit. Currently, NTP is anticipated to be issued on/around March 2009, after MPD 1-D moves to Bowen.

ANSWERS TO OFFERORS QUESTIONS

	<p>4. Where are the core/cores located: center or outside edges of building? 5. Is there a basement (if so what is depth) or is it slab on grade? 6. What is the general thickness/composition of walls, and any special circumstances (extra thick walls) that exist and if so how much? 7. What kind of roof is it and is there any major mech. equip. located there? 8. What is the targeted start date of work?</p>	
<p>58.</p>	<p>Reference: Niedax Cable Management Systems - Cable Tray Substitution Request</p> <p>Is it possible to be added as an acceptable substitution for cable tray? Information on the Niedax cable management systems is provided.</p> <p>The Niedax Group offers more than 3200 standard products for any kind of electrical installation and deals with virtually all of the major national distributors in the electrical market</p>	<p>Please follow substitution requirements outlined in Section 012500 (Substitution Procedures).</p>
<p>59.</p>	<p>Reference: Drawing #A201W – Alternate #11</p> <p>Drawing A201W contains a note in the upper center of the drawing referencing alternate #11 and refers to a bentonite waterproofing spec section 071710. There is no specification by that number. Also there is no alternate #11 listed on the list of alternates. Is this note applicable to this project? Please advise?</p>	<p>Alternate #11 does not exist. Disregard the note on Dwg #A201W referring to Alternate #11.</p> <p>Refer to Sections 071326 and 071700 on approved Waterproofing systems. Contractor may use either system listed.</p>
<p>60.</p>	<p>Reference: Section 074213 & 089250</p> <p>Specification 074213 page 1 paragraph 1.1C & 089250 pages 12 paragraph 1.6N refers to section 088010-Blast Resistant Glazing and Blast requirement. Section 088010 is titled Interior Glazing. Please clarify is there are any blast requirement and identify on the drawings?</p>	<p>There is no blast criteria for the exterior wall. Progressive collapse has been integrated into the structural design. Bullet resistant glass has been incorporated at the guard booth as indicated.</p> <p>Revise the reference to Section 088010 from "Blast Resistant Glazing and Blast requirement" to match Section 088010 current title "Interior Glazing" in specification 074213 page 1 paragraph 1.1C & 089250 pages 12 paragraph 1.6N.</p>

ANSWERS TO OFFERORS QUESTIONS

61.	Can alternative manufacturers for the workstations be offered / accepted?	Please follow substitution requirements outlined in Section 012500 (Substitution Procedures).
62.	Reference: Spec. Section 11 53 10 Firing Range The bullet trap is a proprietary item. Will other manufacturers be considered? Attached is a substitution request for the Meggitt Training Systems Model LE4000.	The A/E is amenable to reviewing additional vendors for the bullet trap. The substitution must be a wet trap and meet the specified criteria. The proposed substitution request for the bullet snail trap is unacceptable as the product does not meet design requirement.
63.	Reference: Drawing A902 Partition Types M & Q indicate the walls to be fully grouted. It's highly unusual to do this in non structural c.m.u. walls. Please verify if this is truly the intent.	In general, the walls do not need to be fully grouted. The walls need to be grouted as required to meet the structural requirements and fire ratings as occurs. The two-hour wall shall meet or exceed the requirements for UL U905.
64.	Reference: High Density Storage Missing from the furniture specifications sheets is the specifications page for the Spacesaver high density storage unit for room 2048. The shelving spec pages are numbered 1 thru 11, and there are 12 rooms that are receiving this high density shelving. Please let me know how to go about getting this page.	The high-density shelving is specified in sections 105626 & 105613. The layout drawings showing the size and scope are shown at the end of section 120600. All three Sections are referenced.
65.	Reference: Section 014500 Façade Mock-up testing Provide information regarding type of mock-up testing required. Will there be one mock-up test required for the north and another one for the south side. If a similar system has been tested, will a test report be acceptable. Please advice	Reference the attached revised specification Section 014500 (Façade Mock-Up Testing), dated 10/17/08 for clarification on the façade mock-up and testing.
66.	Reference: Section 074213 Section 074213 paragraph 2.1-A.2.b panels shall be finished monolithic aluminum... not less than 0.125 inch thick and material legend on A511 calls out metal panels as composite aluminum panel. Section details on A751 through A755 also call out panels as composite aluminum panels. Please confirm if composite metal panels manufactured by Alucobond, Reynobond and Alpollic are acceptable.	Aluminum Panels shall be composite panels. Reference attached revised specification. Delete Section 074213 - Preformed Metal Panel specification and replace with new Section 074300 - Composite Metal Panel specification.

ANSWERS TO OFFERORS QUESTIONS

67.	<p>Reference: Section 074213 Metal Panels</p> <p>Section 074213 page 22-paragraph F.6 indicate window washing stage tieback. Drawings do not show location and spacing of the tiebacks on the metal panels. Please provide.</p>	<p>Delete Section 074213 - Preformed Metal Panel specification and replace with new Section 074300 - Composite Metal Panel specification.</p>
68.	<p>Reference: Electrical – Multi-Tub Panels</p> <p>Panel schedules on Dwgs. E705 -709, E711-713,E715-718,E720-721,E723-724,E726-728 indicate (54) 225A 208V and (2)1200A and 480V multi-section panels or tubs, however the risers do not reflect these as being multi-sectional. The floor plans show (10) of these 225A panels as being 2-section, these are not located adjacent to each other and connected by nipple's ,which is how most 2-section panels are typically oriented and connected. Please confirm the remaining (44) section (tub) panels are located adjacent to each other and only requiring nipple connections.</p>	<p>Follow the Panel Schedules as Risers do not need to depict multi-tubs. The double tub panels shown separated are in the Lab areas as coordinated with the Architect for acceptable locations. They are separated because the walls at these locations were not long enough to support adjacent double tub panels. Double tub Lab Panels shown adjacent to each other were also coordinated for acceptable locations. All double tub panels in Mechanical and Electrical spaces may be adjacent to each other.</p>
69.	<p>Reference Duct Construction Standards</p> <p>1) Specification section 233113 indicates various references to Chapters and Figure# are inconsistent when matched to the latest version (2005- Third Edition) of SMACNA's "HVAC Duct Construction Standards –Metal & Flexible" due to changes made between the 1995-2nd Edition and the 2005- 3rd Edition. There are some statements that infer reference to the 1985- 1st Edition. Please confirm the basis of installation?</p> <p>2) Specification section 233113 references to SMACNA Industrial duct standards for negative pressure duct construction. Please confirm it is acceptable to use SMACNA's "HVAC Duct Construction Standards –Metal & Flexible" as the basis for construction of ducts up to 10" w.g.</p> <p>3) Please confirm that all exhaust systems on this project are designed to carry air with no significant solids, particulates or abrasives.</p>	<p>Revised Specification 233113 is attached to this amendment.</p> <ol style="list-style-type: none"> 1. The basis of installation for metal ducts will be from the latest version, "SMACNA's "HVAC Duct Construction Standards - Metal and Flexible - Third Edition 2005". The specification will be updated accordingly. 2. It is acceptable to use "SMACNA's "HVAC Duct Construction Standards - Metal and Flexible - Third Edition 2005", for negative ducts up to 10" W.C. The specification will be updated accordingly. 3. All duct systems in the building air designed to handle only air. No duct systems will carry solids, particulates, or abrasives.

ANSWERS TO OFFERORS QUESTIONS

<p>70.</p>	<p>Reference Demountable Partitions Substitution Request</p> <p>Attached please find the completed substitution request form from Accent Architectural requesting that their product be approved in place of the specified requirements for demountable partitions. Attached please find the necessary documentation to support that their product is of equal or greater value.</p> <p>Please advise as to whether this product is an acceptable product substitute or not</p>	<p>Per the specifications, 102219-2.1-A, no substitutions will be allowed for demountable partitions.</p>
<p>71.</p>	<p>Reference Demountable Partitions Substitution Request</p> <p>Attached please find the completed substitution request form from Acme Architectural Walls requesting that their product be approved in place of the specified requirements for demountable partitions. Attached please find the necessary documentation to support that their product is of equal or greater value.</p> <p>Please advise as to whether this product is an acceptable product substitute or not.</p>	<p>Per specifications 102219-2.1-A, no substitutions will be allowed for demountable partitions.</p>
<p>72.</p>	<p>Reference Demountable Partitions Substitution Request</p> <p>Attached please find the completed substitution request form from Haworth, Inc. requesting that their product be approved in place of the specified requirements for demountable partitions. Attached please find the necessary documentation to support that their product is of equal or greater value.</p> <p>Please advise as to whether this product is an acceptable product substitute or not</p>	<p>Per the specifications, 102219-2.1-A, no substitutions will be allowed for demountable partitions.</p>

ANSWERS TO OFFERORS QUESTIONS

73.	<p>Reference Roller Window Shades Substitution Request</p> <p>Attached please find the completed substitution request form from Contract Decor requesting that their product be approved in place of the specified requirements for roller window shades. Attached please find the necessary documentation to support that their product is of equal or greater value.</p> <p>Please advise as to whether this product is an acceptable product substitute or not</p>	<p>The proposed substitution request for roller shades (Contract Décor) is acceptable. The proposed manufacturer's product will be added as an approved product. The manufacturer needs to show that they will comply with all of the criteria in the technical specifications.</p>
74.	<p>Reference: Door types- A961</p> <p>Door Schedule Section 087110 shows type "U" & "W" doors, but drawing A961 does not show these types of doors. Please clarify?</p>	<p>- Doors listed as type 'U' shall be type 'T' - Doors listed as type 'W' shall be type 'A' if single doors and type 'B' if double doors.</p>
75.	<p>Reference Question #48, Amendment No. 04</p> <p>Question #48 response revised liquidated damages being assessed from Final Acceptance to Substantial Completion. If so, the performance period of the contract has essentially been reduced by approximately 60 days, is this the intent?</p>	<p>This response supersedes Item. b., in Question #48, Amendment No. 04.</p> <p>Reference Section H.2.1 - Remove "Liquated Damages only apply to the Substantial Completion Milestone" and replace it back with the original text included in the solicitation that reads "Liquated Damages only apply to the Final Acceptance Milestone".</p>
76.	<p>Reference: Site Utility/Demolition Drawing C-4.0/C-5.0</p> <p>A. Note 24 on C-4.0 indicate to remove the existing storm lines at the rear of the Firehouse. They still show on the Site Utility drawing – C-5.0. Please Clarify?</p> <p>B. Note 24 on C-4.0 at the north side of the firehouse is the same as note 1. Is this an error? Please clarify?</p> <p>C. Note 21 on C-4.0 indicate relocating a telephone line north of the firehouse. Site utility drawing doesn't show where to. Please clarify?</p> <p>D. What happens to the 550 gallon gas tank at the rear of the firehouse?</p> <p>E. Note 1 on C-4.0 points toward the curb on School Street. Should it refer to the 21" storm drain or is there another line not shown? Please clarify?</p>	<p>Refer to revised Drawings C-4.0 and C-5.0 issued as part of this Amendment (No. 05).</p>

ANSWERS TO OFFERORS QUESTIONS

77.	<p>Reference: Drawings E701 and E702 - lighting fixture schedule:</p> <ul style="list-style-type: none">a. The plan drawings reference a fixture type PL1a. This fixture does not exist in the fixture schedule. Please clarify?b. The plan drawings reference a fixture type VP6A. This fixture does not exist in the fixture schedule. Please clarify?c. In the News Room, fixture type ZZ1 indicates theatrical light holders, but does not specify the fixture to be supplied with the pipe holder. Please clarify.d. On Dwg. E207E, there is a symbol listed as GRX in room 5020. We cannot locate the specification or definition of this device. Please clarify?	<p>Refer to revised Drawings E702 & E207E (including revised fixtures schedule) issued as part of this Amendment (No. 05).</p>
-----	--	--

Attachment B

**New/Revised Drawings and Specification List
Attachment B**

#	Sheet Number	Drawing Title
Volume 1		
1	C4.0	UTILITY DEMOLITION PLAN
2	C5.0	SITE UTILITY PLAN
3	C5.1	UTILITY PROFILES-1
4	C5.2	UTILITY PROFILES-2
5	C5.3	UTILITY DETAILS-1
6	C5.7	WASA INFORMATION
7	C6.0	Sandfilter
8	C6.1	Sandfilter Reinforcing
9	C6.2	Sandfilter Reinforcement Plan
10	C6.3	Sandfilter Typical Details
11	C6.4	Stormwater Management Calculations
12	C6.5	AREA DRAINAGE MAP
13	C6.6	Green Roof Maintenance
14	C10.1	EROSION AND SEDIMENT CONTROL NOTES
15	S103E	EDGE OF SLAB LEVEL 1 EAST
16	S103W	EDGE OF SLAB LEVEL 1 WEST
17	S104W	EDGE OF SLAB LEVEL 2 WEST
18	S109W	EDGE OF SLAB UPPER PENTHOUSE WEST
19	S203E	FLOOR FRAMING PLAN LEVEL 1 EAST
20	S203W	FLOOR FRAMING PLAN LEVEL 1 WEST
21	S204W	FLOOR FRAMING PLAN LEVEL 2 WEST
22	S209W	FLOOR FRAMING PLAN UPPER PENTHOUSE WEST
23	S501	COLUMN SCHEDULE
24	S704	SECTIONS AND DETAILS
25	S705	SECTIONS AND DETAILS
26	S706	SECTIONS AND DETAILS
27	S712	SECTIONS AND DETAILS
28	S714	SECTIONS AND DETAILS
Volume 2		
29	G201	GENERAL NOTES, ABBREVIATIONS, AND SYMBOLS
30	G202	ACCESSORIES DETAILS
31	G203	PLAT SUBDIVISION
32	A201E	FLOOR PLAN - LEVEL B2 EAST
33	A201W	FLOOR PLAN - LEVEL B2 WEST
34	A202E	FLOOR PLAN - LEVEL B1 EAST
35	A202W	FLOOR PLAN - LEVEL B1 WEST
36	A203E	FLOOR PLAN - LEVEL 1 EAST
37	A203W	FLOOR PLAN - LEVEL 1 WEST
38	A204E	FLOOR PLAN - LEVEL 2 EAST
39	A204W	FLOOR PLAN - LEVEL 2 WEST
40	A205E	FLOOR PLAN - LEVEL 3 EAST
41	A206E	FLOOR PLAN - LEVEL 4 EAST
42	A206W	FLOOR PLAN - LEVEL 4 WEST
43	A207E	FLOOR PLAN - LEVEL 5 EAST
44	A207W	FLOOR PLAN - LEVEL 5 WEST
45	A208E	FLOOR PLAN - LEVEL 6 - LOWER PENTHOUSE EAST

46	A208W	FLOOR PLAN - LEVEL 6 - LOWER PENTHOUSE WEST
47	A209E	FLOOR PLAN - UPPER PENTHOUSE EAST
48	A209W	FLOOR PLAN - UPPER PENTHOUSE WEST
49	A210E	FLOOR PLAN - ROOF EAST
50	A210W	FLOOR PLAN - ROOF WEST
51	A302E	REFLECTED CEILING PLAN - LEVEL B1 EAST
52	A302W	REFLECTED CEILING PLAN - LEVEL B1 WEST
53	A303E	REFLECTED CEILING PLAN - LEVEL 1 EAST
54	A303W	REFLECTED CEILING PLAN - LEVEL 1 WEST
55	A304E	REFLECTED CEILING PLAN - LEVEL 2 EAST
56	A304W	REFLECTED CEILING PLAN - LEVEL 2 WEST
57	A305E	REFLECTED CEILING PLAN - LEVEL 3 EAST
58	A305W	REFLECTED CEILING PLAN - LEVEL 3 WEST
59	A306E	REFLECTED CEILING PLAN - LEVEL 4 EAST
60	A306W	REFLECTED CEILING PLAN - LEVEL 4 WEST
61	A307E	REFLECTED CEILING PLAN - LEVEL 5 EAST
62	A307W	REFLECTED CEILING PLAN - LEVEL 5 WEST
63	A308E	REFLECTED CEILING PLAN - LEVEL 6 EAST
64	A308W	REFLECTED CEILING PLAN - LEVEL 6 WEST
65	A401	ENLARGED PLANS - CORE A
66	A403	ENLARGED PLANS - CORE B
67	A407	ENLARGED PLANS
68	A431	ENLARGED STAIR & ELEVATOR SECTION - CORE A
69	A436	ENLARGED ELEVATOR SECTION - CORE B
70	A438	ENLARGED SECTION - VEHICLE ELEVATOR
71	A441	ENLARGED PLANS - TOILET ROOMS
72	A462	ENLARGED REFLECTED CEILING PLANS
73	A511	EAST ELEVATION - ENLARGED VIEW
74	A512E	SOUTH ELEVATION EAST
75	A512W	SOUTH ELEVATION WEST
76	A514E	NORTH ELEVATION EAST
77	A514W	NORTH ELEVATION WEST
78	A516	EXT ELEVATIONS
79	A722	ENLARGED EXTERIOR WALL SECTIONS - EAST FACADE
80	A724	ENLARGED EXTERIOR WALL SECTIONS - EAST FACADE
81	A733	ENLARGED EXTERIOR WALL SECTIONS - SOUTH FACADE
82	A735	ENLARGED EXTERIOR WALL SECTIONS - SOUTH FACADE
83	A736	ENLARGED EXTERIOR WALL SECTIONS - SOUTH ATRIUM
84	A742	ENLARGED EXTERIOR WALL SECTIONS - WEST FACADE
85	A743	ENLARGED EXTERIOR WALL SECTIONS - WEST FACADE
86	A744	ENLARGED EXTERIOR WALL SECTIONS - WEST FACADE
87	A751	ENLARGED EXTERIOR WALL SECTIONS - NORTH FACADE
88	A753	ENLARGED EXTERIOR WALL SECTIONS - NORTH FACADE
89	A754	ENLARGED EXTERIOR WALL SECTIONS - NORTH FACADE
90	A755	ENLARGED EXTERIOR WALL SECTION - NORTH COOLING TOWER
91	A771	EXTERIOR WALL DETAILS - EAST/WEST FACADE
92	A772	EXTERIOR WALL DETAILS - SOUTH FACADE
93	A775	EXTERIOR WALL DETAILS - NORTH FACADE
94	A791	MISC SECTION DETAILS
95	A792	TYPICAL BELOW GRADE WATERPROOFING DETAILS
96	A813	PLAN DETAILS - LEVEL 1 - SOUTH FACADE
97	A816	PLAN DETAILS. MISC. - SECURITY BOOTH
98	A817	PLAN DETAILS - LEVEL 1 - ATRIUM

99	A818	Plan Details Level 1 Atrium
100	A821	PLAN DETAILS - LEVEL 2
101	A822	PLAN DETAILS - LEVEL 2 THRU 5 - EAST FACADE
102	A824	PLAN DETAILS - LEVEL 2 THRU 5 - SOUTH FACADE
103	A841	PLAN DETAILS - LOWER ROOF
104	A852	PLAN & SECTION DETAILS OF GATE
105	A861	ENLARGED PLAN DETAILS
Volume 3		
106	A929	ROOM FINISH SCHEDULE
107	A943	STAIR DETAILS
108	A947	ELEVATOR DETAILS
109	A961	DOOR AND WINDOW TYPES
110	A964	DOOR DETAILS
111	I103E	PARTIAL FIRST FLOOR FURNITURE PLAN
112	I103W	PARTIAL FIRST FLOOR FURNITURE PLAN
113	I104E	PARTIAL SECOND FLOOR FURNITURE PLAN
114	I104W	PARTIAL SECOND FLOOR FURNITURE PLAN
115	I105E	PARTIAL THIRD FLOOR FURNITURE PLAN
116	I105W	PARTIAL THIRD FLOOR FURNITURE PLAN
117	I106E	PARTIAL FOURTH FLOOR FURNITURE PLAN
118	I106W	PARTIAL FOURTH FLOOR FURNITURE PLAN
119	I107E	PARTIAL FIFTH FLOOR FURNITURE PLAN
120	I107W	PARTIAL FIFTH FLOOR FURNITURE PLAN
121	I108E	PARTIAL SIXTH FLOOR FURNITURE PLAN
122	I108W	PARTIAL SIXTH FLOOR FURNITURE PLAN
123	GR101	EXTERIOR SIGNAGE
124	GR109	SIGN LOCATION PLAN LEVEL 1
125	QL001	GENERAL NOTES, ABBREV, AND SYMBOLS
126	QL002	GENERAL NOTES, ABBREV, AND SYMBOLS
127	QL103	FIREARMS & TRACE MODULAR WORKSTATIONS
128	QL453b	ENLARGED PARTIAL PLAN - LEVEL 1
129	QL454a	ENLARGED PARTIAL PLAN - LEVEL 2
130	QL454b	ENLARGED PARTIAL PLAN - LEVEL 2
131	QL454c	ENLARGED PARTIAL PLAN - LEVEL 2
132	QL455b	ENLARGED PARTIAL PLAN - LEVEL 3
133	QL456b	ENLARGED PARTIAL PLAN - LEVEL 4
134	QL605	INTERIOR LAB ELEVATIONS
Volume 4		
135	P101	Plumbing Plot Plan
136	P-210E	ROOF PLAN - EAST
137	P-210W	ROOF PLAN - WEST
138	P-451a	ENLARGED PARTIAL PLAN - LEVEL B2
139	P-451b	ENLARGED PARTIAL PLAN - LEVEL B2
140	P-451d	ENLARGED PARTIAL PLAN - LEVEL B2
141	P-452a	ENLARGED PARTIAL PLAN - LEVEL B1
142	P-452b	ENLARGED PARTIAL PLAN - LEVEL B1
143	P-452d	ENLARGED PARTIAL PLAN - LEVEL B1
144	P-453a	ENLARGED PARTIAL PLAN - LEVEL 1
145	P-453b	ENLARGED PARTIAL PLAN - LEVEL 1
146	P-453c	ENLARGED PARTIAL PLAN - LEVEL 1
147	P-454a	ENLARGED PARTIAL PLAN - LEVEL 2
148	P-454b	ENLARGED PARTIAL PLAN - LEVEL 2
149	P-454c	ENLARGED PARTIAL PLAN - LEVEL 2

150	P-455a	ENLARGED PARTIAL PLAN - LEVEL 3
151	P-455b	ENLARGED PARTIAL PLAN - LEVEL 3
152	P-455c	ENLARGED PARTIAL PLAN - LEVEL 3
153	P-456a	ENLARGED PARTIAL PLAN - LEVEL 4
154	P-456b	ENLARGED PARTIAL PLAN - LEVEL 4
155	P-456c	ENLARGED PARTIAL PLAN - LEVEL 4
156	P-457a	ENLARGED PARTIAL PLAN - LEVEL 5
157	P-457b	ENLARGED PARTIAL PLAN - LEVEL 5
158	P-457c	ENLARGED PARTIAL PLAN - LEVEL 5
159	P-457f	ENLARGED PARTIAL PLAN - LEVEL 5
160	P-458a	ENLARGED PARTIAL PLAN - LEVEL 6/ LOWER PENTHOUSE
161	P-458b	ENLARGED PARTIAL PLAN - LEVEL 6/ LOWER PENTHOUSE
162	P-458c	ENLARGED PARTIAL PLAN - LEVEL 6/ LOWER PENTHOUSE
163	P-459a	ENLARGED PARTIAL PLAN - UPPER PENTHOUSE
164	P-459b	ENLARGED PARTIAL PLAN - UPPER PENTHOUSE
165	P-459c	ENLARGED PARTIAL PLAN - UPPER PENTHOUSE
166	P-501	WATER DISTRIBUTION FLOW DIAGRAM
167	P-506	WATER RECLAIM SYSTEM RISER DIAGRAM - PLUMBING
168	P-507	NATURAL GAS RISER DIAGRAM
169	P-508	SANITARY RISER DIAGRAM
170	P-509	LABORATORY AND BIOHAZARD WASTE RISER DIAGRAM
171	P-510	STORM SYSTEM RISER DIAGRAM - PLUMBING
172	P-606	PLUMBING SCHEDULES & DETAILS
173	P-705	PLUMBING DETAILS & BIOHAZARD WASTE RISER DIAGRAM
174	P-927	INTERIOR LAB PLUMBING ELEVATIONS ELEVATING SINK - LEVEL 5
Volume 5		
175	H002	HVAC LEGEND SHEET 2
176	H201E	HVAC LEVEL B2 PART PLAN EAST
177	H201W	HVAC LEVEL B2 PART PLAN WEST
178	H202E	HVAC LEVEL B1 PART PLAN EAST
179	H202W	HVAC LEVEL B1 PART PLAN WEST
180	H403a	HVAC LEVEL 1 PART PLAN AREA A
181	H403b	HVAC LEVEL 1 PART PLAN AREA B
182	H403c	HVAC LEVEL 1 PART PLAN AREA C
183	H403d	HVAC LEVEL 1 PART PLAN AREA D
184	H403e	HVAC LEVEL 1 PART PLAN AREA E
185	H403f	HVAC LEVEL 1 PART PLAN AREA F
186	H404a	HVAC LEVEL 2 PART PLAN AREA A
187	H404b	HVAC LEVEL 2 PART PLAN AREA B
188	H404c	HVAC LEVEL 2 PART PLAN AREA C
189	H404d	HVAC LEVEL 2 PART PLAN AREA D
190	H404e	HVAC LEVEL 2 PART PLAN AREA E
191	H404f	HVAC LEVEL 2 PART PLAN AREA F
192	H405a	HVAC LEVEL 3 PART PLAN AREA A
193	H405b	HVAC LEVEL 3 PART PLAN AREA B
194	H405c	HVAC LEVEL 3 PART PLAN AREA C
195	H405d	HVAC LEVEL 3 PART PLAN AREA D
196	H405e	HVAC LEVEL 3 PART PLAN AREA E
197	H405f	HVAC LEVEL 3 PART PLAN AREA F
198	H406a	HVAC LEVEL 4 PART PLAN AREA A
199	H406b	HVAC LEVEL 4 PART PLAN AREA B
200	H406c	HVAC LEVEL 4 PART PLAN AREA C
201	H406d	HVAC LEVEL 4 PART PLAN AREA D

202	H406e	HVAC LEVEL 4 PART PLAN AREA E
203	H406f	HVAC LEVEL 4 PART PLAN AREA F
204	H407a	HVAC LEVEL 5 PART PLAN AREA A
205	H407b	HVAC LEVEL 5 PART PLAN AREA B
206	H407c	HVAC LEVEL 5 PART PLAN AREA C
207	H407d	HVAC LEVEL 5 PART PLAN AREA D
208	H407e	HVAC LEVEL 5 PART PLAN AREA E
209	H407f	HVAC LEVEL 5 PART PLAN AREA F
210	H408a	HVAC LEVEL 6 & LOWER PENTHOUSE PART PLAN AREA A
211	H408b	HVAC LEVEL 6 & LOWER PENTHOUSE PART PLAN AREA B
212	H408d	HVAC LEVEL 6 & LOWER PENTHOUSE PART PLAN AREA D
213	H408e	HVAC LEVEL 6 & LOWER PENTHOUSE PART PLAN AREA E
214	H408f	HVAC LEVEL 6 & LOWER PENTHOUSE PART PLAN AREA F
215	H409a	UPPER PENTHOUSE PART PLAN AREA A
216	H409b	UPPER PENTHOUSE PART PLAN AREA B
217	H409c	UPPER PENTHOUSE PART PLAN AREA C
218	H614W	HVAC LEVEL 3 WEST AIRFLOW BALANCE DIAGRAM
219	H703	HVAC SCHEDULE SHEET 3
220	H704	HVAC SCHEDULE SHEET 4
221	H706	HVAC SCHEDULE SHEET 6
222	H707	HVAC SCHEDULE SHEET 7
223	H708	HVAC SCHEDULE SHEET 8
224	H709	HVAC SCHEDULE SHEET 9
225	H710	HVAC SCHEDULE SHEET 10
226	H711	HVAC SCHEDULE SHEET 11
Volume 6		
227	E002	ELECTRICAL LEGEND AND GENERAL NOTES SHEET #2
228	E207E	ELECTRICAL LEVEL 5 LIGHTING PLAN EAST
229	E208E	ELECTRICAL LEVEL 6 & LOWER PENTHOUSE LIGHTING PLAN EAST
230	E405B	ELECTRICAL LEVEL 3 POWER PLAN AREA B
231	E406A	ELECTRICAL LEVEL 4 POWER PLAN AREA A
232	E406B	ELECTRICAL LEVEL 4 POWER PLAN AREA B
233	E407C	ELECTRICAL LEVEL 5 POWER PLAN AREA C
234	E600	ELECTRICAL ONE-LINE DIAGRAM
235	E601	ELECTRICAL POWER RISER DIAGRAM WEST
236	E603E	ELECTRICAL EMERGENCY POWER RISER DIAGRAM EAST
237	E603W	ELECTRICAL EMERGENCY POWER RISER DIAGRAM WEST
238	E702	ELECTRICAL SCHEDULES LIGHTING FIXTURES ELEVATORS SHT. 2B
239	E717	ELECTRICAL SCHEDULES LEVEL 4 PANELBOARDS SHT. 17
240	E725	ELECTRICAL SCHEDULES LEVEL 6 PANELBOARDS SHT. 25
Volume 7		
241	FA-001	FIRE ALARM GENERAL NOTES AND SYMBOLS
242	FA-205W	FIRE ALARM - LEVEL 3 WEST
243	FA-206E	FIRE ALARM - LEVEL 4 EAST
244	FA-207E	FIRE ALARM - LEVEL 5 EAST
245	FP-201E	FIRE PROTECTION - LEVEL B2 EAST
246	FP-201W	FIRE PROTECTION - LEVEL B2 WEST
247	FP-202W	FIRE PROTECTION - LEVEL B1 WEST
248	FP-203E	FIRE PROTECTION - LEVEL 1 EAST
249	FP-204W	FIRE PROTECTION - LEVEL 2 WEST
250	FP-205W	FIRE PROTECTION - LEVEL 3 WEST
251	FP-207E	FIRE PROTECTION - LEVEL 5 EAST
252	T4.0.01	LEVEL 4 COMMUNICATIONS OUTLETS PLAN AREA 1

253	T4.0.02	LEVEL 4 COMMUNICATIONS OUTLETS PLAN AREA 2
254	SC106	SECURITY COMPOSITE FLOOR PLAN - LEVEL 4
255	SC107	SECURITY COMPOSITE FLOOR PLAN - LEVEL 5
256	SC303	SECURITY RISER
#	Spec Number	Specification Section
Volume 1		
1	01 45 00	FAÇADE MOCK-UP TESTING
2	04 85 10	DIMENSIONAL STONE CLADDING
3	07 43 00	COMPOSITE METAL WALL PANELS
4	07 84 53	FAÇADE INSULATION SAFING
5	07 92 00	EXTERIOR FAÇADE SEALANTS
Volume 2		
6	08 14 16	FLUSH WOOD DOORS
7	08 41 13	ALUMINUM FRAMED STOREFRONTS
8	08 41 26	ALL-GLASS ENTRANCES AND STOREFRONTS
9	08 44 13	GLAZED ALUMINUM WALL SYSTEMS
10	08 63 10	STRUCTURAL GLASS CANOPIES
11	08 80 00	GLASS GLAZING
12	08 92 50	PATCH PLATE SUPPORTED GLAZING SYSTEM
13	10 14 10	SIGN MESSAGE SCHEDULE
14	10 71 13	SUN SCREENS
15	11 05 13	COMMON MOTOR REQUIREMENTS FOR EQUIPMENT
16	11 53 13	LABORATORY FUME HOODS
17	13 21 00	ENVIRONMENTAL ROOMS
Volume 5		
18	23 31 13	METAL DUCTS
19	23 33 00	AIR DUCT ACCESSORIES
20	32 31 19	DECORATIVE METAL GATES

- a. These files are posted electronically and can be downloaded from the link below:
(<ftp://ForensicBid:OS3OfU5q@ftp.jacobs.com/>)
- b. The revised drawings and specifications included in Bid Amendment #5 are marked "BID AMENDMENT NO. 05, ISSUED OCT 30, 2008" capture clarifications from permit review process, Offerors questions and other corrections.
- c. The dates & notations in the title block of the drawings issued under Amendment No. 05 (Permit Revision, Permit Revision A, Addendum #1, etc.) denote internal A/E tracking mechanism.

Attachment C

1. MPD First District (1-D) Condition Building Assessment report, dated 8/31/2005 (Attachment "C"):
 - a. This attachment is issued in response to Question #57
 - b. Attachment "C" is also posted electronically and can be downloaded from the link below:
[\(ftp://ForensicBid:OS3OfU5q@ftp.jacobs.com/\)](ftp://ForensicBid:OS3OfU5q@ftp.jacobs.com/)