

| | | | | | |
|--|--|--------------------------------|--|---|------------------|
| AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT | | | 1. Contract Number | Page of Pages 1 4 | |
| 2. Amendment/Modification Number DCAM-2009-B-0036-M03 | | 3. Effective Date 18-Jun-09 | | 4. Requisition/Purchase Request No. | |
| 5. Solicitation Caption See Caption Below | | | | | |
| 6. Issued By: Office of Property Management 2000 14th Street, N.W., 8th Floor Washington, DC 20009 | | Code | | 7. Administered By (If other than line 6) Office of Property Management 2000 14th Street, N.W., 8th Floor Washington, DC 20009 | |
| 8. Name and Address of Contractor (No. Street, city, country, state and ZIP Code) | | | (X) | 9A. Amendment of Solicitation No. DCAM-2009-B-0036 | |
| | | | | 9B. Dated (See Item 11) 8-May-09 | |
| | | | | 10A. Modification of Contract/Order No. | |
| | | | | 10B. Dated (See Item 13) | |
| Code | | Facility | | | |
| 11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS | | | | | |
| <input type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended. <input checked="" type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or fax which includes a reference to the solicitation and amendment number. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or fax, provided each letter or telegram makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified. | | | | | |
| 12. Accounting and Appropriation Data (If Required) | | | | | |
| 13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14 | | | | | |
| A. This change order is issued pursuant to: (Specify Authority) | | | | | |
| The changes set forth in Item 14 are made in the contract/order no. in item 10A. | | | | | |
| B. The above numbered contract/order is modified to reflect the administrative changes (such as changes in paying office, appropriation date, etc.) set forth in item 14, pursuant to the authority of 27 DCMR, Chapter 36, Section 3601.2. | | | | | |
| C. This supplemental agreement is entered into pursuant to authority of: | | | | | |
| D. Other (Specify type of modification and authority) | | | | | |
| E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office. | | | | | |
| 14. Description of amendment/modification (Organized by UCF Section headings, including solicitation/contract subject matter where feasible.) | | | | | |
| Solicitation No. DCAM-2009-B-0036 Reeves Center First Floor Build-Out, is hereby amended as follows: | | | | | |
| (1) Questions and Answers (Attachment A) | | | | | |
| (2) All other terms and conditions remain the same. | | | | | |
| Except as provided herein, all terms and conditions of the document referenced in Item (9A or 10A) remain unchanged and in full force and effect | | | | | |
| 15A. Name and Title of Signer (Type or print) | | | 16A. Name of Contracting Officer Diane Wooden | | |
| 15B. Name of Contractor | | 15C. Date Signed | 16B. District of Columbia | | 16C. Date Signed |
| (Signature of person authorized to sign) | | | <i>Diane Wooden</i> | | 6/18/09 |
| | | | (Signature of Contracting Officer) | | |

Attachment A

REEVES CENTER FIRST FLOOR BUILD-OUT

SOLICITATION NO: DCAM-2009-B-0036

QUESTIONS AND ANSWERS

| NO. | IFB SECTION | RFI # | Questions | Response |
|-----|-------------|-------|---|---|
| 1 | | #1 | Please be advised Section No. 08210 Flush Wood Doors is missing from the Project Manual for the Solicitation No. DCAM-2009-B-0036, Reeves Center. We would appreciate if the section could be emailed. | Section No. 08210 Flush Wood Doors will be provided |
| 2 | | #3 | PG A5 – Drawings. Doors #105, 106 and 140 are indicated to be 3070 wood doors but the hardware & door type are indicated as glass doors, please clarify. | Doors 105, 106 and 140 are glass doors |
| 3 | | #4 | PG A3 – Between Col. 4 and 5 1/2 and Col. B and C – clear area ceiling in Open Office 107 is indicated as ACT where as all other clear areas appear to be Gyp. Should this area also be Gypsum, please clarify. | Open office 107 and Corridor 106 ceiling to be Gypsum board as indicated on A-3. |
| 4 | | #6 | PG A6- RM#121 - Elevation 5/A-6 shows frosted glass at existing storefront. Can Contractor use film on existing glass? If so, please specify film type? | We are using on-site sandblasting for the glass 6'-6" above finish floor |
| 5 | | #7 | Also RM#121 – The verbiage ‘Frosted glass typical for perimeter glass only’ – Contractor’s assumption is that all perimeter glass around RM#121 would get frosted glass – is this correct? | All perimeter glass to be frosted except the rear perimeter exterior wall only. |
| 6 | | #8 | PG A6-Elevations 6, 7, 8 and 9 – indicate “Reeded Glass”; please provide specifications and contact information for this product. | Reeded glass to be 1/4" tempered |

REEVES CENTER FIRST FLOOR BUILD-OUT

SOLICITATION NO: DCAM-2009-B-0036

QUESTIONS AND ANSWERS

| NO. | IFB SECTION | RFI # | Questions | Response |
|-----|-------------|-------|---|---|
| 7 | | #9 | PG A6-Elevation 6/A-6 – indicates glass in Office #129 – no new glass is shown in this office other than a sidelight on Floor Plan A1. Does this elevation refer to perimeter glass? Please clarify. | The plan indicates glass on the corridor side of Office 129 |
| 8 | | #10 | The Lighting Fixture Schedule, Drawing# E-1, the Vendor Lightolier does not have the part number listed. Either the part number is incorrect or the Vendor is wrong. Please with the correct Vendor and Part Number. | Please refer to the architectural drawing A-3 for correct lighting schedule information. Basement lights need to be included in schedule. Will provide |
| 9 | | #18 | Reflected ceiling plans indicate that an acoustical tile ceiling with recessed incandescent fixtures is to be installed in open office area #107 and in corridor #106. The plan symbol is for a drywall ceiling in these places. Please clarify | Open Office 107 and Corridor 106 to have gypsum ceiling |
| 10 | | #19 | All door details indicate 5/8” drywall, yet all partition details on drawing A-4 indicates 1/2 “ drywall. Please clarify. | All drywall partitions are to be 1/2”. |
| 11 | | #20 | These details indicate that 2 1/2” wide trim is to be used on aluminum frames, yet the Jamb details on the sheet shows 2” wide trim. Please clarify. | All interior aluminum frames are to have 2” wide trim. |
| 12 | | #21 | Partition type S1, S1A, S2, S3 and S7 on page A-4 shows continuous ceiling track under grid and at the deck. Are any walls framed under ceiling grid? If not then clarify partition schedule. If partitions are framed to deck then at least 6" GWB should be above drop ceiling. Wall type S3 is listed as a rated wall, please clarify; | All S1 wall types are framed under the grid. S3 is a 1 hour fire rated wall. |

REEVES CENTER FIRST FLOOR BUILD-OUT

SOLICITATION NO: DCAM-2009-B-0036

QUESTIONS AND ANSWERS

| NO. | IFB SECTION | RFI # | Questions | Response |
|-----|-------------|-------|---|--|
| 13 | | #22 | <p>Plumbing;</p> <p>a) Provide specification for shower valves and basin;</p> <p>b) Is there a floor below Men's and Women's toilet room? Or is it on slab on grade?</p> <p>c) Are lavatories in Men's and Women's toilet room wall hung or counter top type?</p> <p>d) Please clarify ADA shower type. Plumbing drawing shows a SH-3 but not listed in fixture schedule.</p> | <p>a) Typical specifications for shower valve and basin can be used.</p> <p>b) There is a floor below this level.</p> <p>c) counter top type lavatories</p> <p>d) Shower Type to be Model APES3698BF625 with ADA compliant shower head as specified for this model type.</p> |
| 14 | | #23 | <p>Aluminum Storefront:</p> <p>Door type # 8 calls for glass" balanced doors" with HWD set # W2. Balance doors are extremely expensive. Can we use a typical aluminum/storefront and wood door assembly? Hardware W2 does not correspond to Balance door assembly. Are there any Door Type # 3?</p> | <p>All glass doors shall be balanced. Will provide correct hardware set to correspond with balanced doors</p> <p>There is no door type #3</p> |
| 15 | | #25 | <p>Would you please provide the specifications for the wood doors required for this project?</p> | <p>The Section No. 08210 Flush Wood Doors will be provided</p> |
| 16 | | | <p>Detail 10/A-8 shows new "Mecho" Shades, are "Mecho" shades in the contractor's scope of work? If so, please provide locations of shades on the Reflected Ceiling Plan.</p> | <p>Yes, Mecho Shades are in the contractor's scope. Mecho shades will be installed on the exterior side of the space facing rear courtyard, which is the West side of the building.</p> |