

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. Contract Number DCAM-2010-B-0130	Page of Pages 1 2
2. Amendment/Modification Number DCAM-2010-B-0130-001	3. Effective Date June 10, 2010	4. Requisition/Purchase Request No.		5. Solicitation Caption Eastern Market-Market Master's Office Rehabilitation
6. Issued By: Department of Real Estate Services Contracting and Procurement Division 2000 14th Street, NW, 5th Floor Washington, DC 20009		7. Administered By (If other than line 6) Department of Real Estate Services Capital Construction Division 2000 14th Street, NW, 8th Floor Washington, DC 20009		
8. Name and Address of Contractor (No. Street, city, country, state and ZIP Code)			9A. Amendment of Solicitation No. DCAM-2010-B-0130	
			X 9B. Dated (See Item 11) 5/15/2010	
			10A. Modification of Contract/Order No.	
			10B. Dated (See Item 13)	
Code	Facility		11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS	
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or fax which includes a reference to the solicitation and amendment number. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or fax, provided each letter or telegram makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
12. Accounting and Appropriation Data (If Required)				
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14				
A. This change order is issued pursuant to: (Specify Authority) The changes set forth in Item 14 are made in the contract/order no. in item 10A.				
B. The above numbered contract/order is modified to reflect the administrative changes (such as changes in paying office, appropriation date, etc.) set forth in item 14, pursuant to the authority of 27 DCMR, Chapter 36, Section 3601.2.				
C. This supplemental agreement is entered into pursuant to authority of:				
D. Other (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input checked="" type="checkbox"/> is required to sign this document and return <u>1</u> copy to the issuing office.				
14. Description of amendment/modification (Organized by UCF Section headings, including solicitation/contract subject matter where feasible.)				
1. The date for submission of bids is hereby extended from June 15, 2010, by 2:00 p.m. local time to June 18, 2010 by 2:00 p.m. local time.				
2. See Page 2 for Bidder questions and answers.				
3. All other terms and conditions remain unchanged.				
15A. Name and Title of Signer (Type or print)			16A. Name of Contracting Officer Diane Wooden	
15B. Name of Contractor (Signature of person authorized to sign)		15C. Date Signed	16B. District of Columbia <i>Diane Wooden</i> (Signature of Contracting Officer)	
			16C. Date Signed <i>6/10/10</i>	

No.	Bidders' Question	AE Response
1.	Drawings – depict wiring diagram(s) from the junction box to the 2 nd Floor. Master’s Office to show how the contractors can comply with the electrical (raceways) solicitation requirements.	Existing Panel P2 is located on the 1 st floor in the office below where indicated in details 2 & 3/E101. Contractor to verify in field.
2.	Specification for Electrical Conduit going to the 2 nd Floor Master’s Office?	Specification 260500 (Basic Electrical Materials and Methods) describes some of the requirements for raceways as does spec. 260533 (Raceways and Boxes) along with spec. 260534 (Surface Mounted Raceways). These 3 specs fully cover the raceway requirements.
3.	Specification for Casing Wood, can contractor restore or is total replacement required?	<p>All casing wood is existing to remain and to be painted, per keynote 09-06. Wood repair is required at transom window head per detail A1/102, photo detail 11/A101.</p> <p>Wood baseboard is existing to remain; except where baseboard is missing, provide wood baseboard to match existing adjacent per keynote 06-03, estimate 4 LF.</p>
4.	Permitting-is the contractor required to obtain permits, or will DRES obtain permits?	<p>Building permit has been obtained.</p> <p>See Solicitation Section H.3 for additional contractor permits required.</p>
5.	Does the government estimate include any abatement requirement?	Abatement work of asbestos and lead-containing materials was completed in previous rehabilitation project when windows were restored and repainted.