

AMENDMENT OF SOLICITATION / MODIFICATION OF CONTRACT				1. Contract Number		Page of Pages	
						1 3	
2. Amendment/Modification Number		3. Effective Date		4. Requisition/Purchase Request No.		5. Solicitation Caption	
DCFB-2008-B-0037-003		April 21, 2008				Renovation and Modernization of Engine Company Number 28	
6. Issued by:				Code			
Office of Contracting and Procurement Construction, Design and Building Renovation 441 4 th Street, NW, Suite 700S Washington, DC 20001				LRT			
7. Administered by (If other than line 6)							
Office of Contracting and Procurement Construction, Design and Building Renovation 441 4 th Street, NW, Suite 700S Washington, DC 20001							
8. Name and Address of Contractor (No. street, city, county, state and zip code)				9A. Amendment of Solicitation No.			
				DCFB-2008-0037			
				9B. Dated (See Item 11)			
				March 24, 2008			
				10A. Modification of Contract/Order No.			
Code				10B. Dated (See Item 13)			
DUNS:				TIN			
FEIN:							
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended <input checked="" type="checkbox"/> is not extended. Offeror's must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning <u>2</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) BY separate letter or fax which includes a reference to the solicitation and amendment number. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such may be made by letter or fax, provided each letter or telegram makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. Accounting and Appropriation Data (If Required) <i>To be cited on individual orders issued on behalf of participating agencies</i>							
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS , IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14							
X	A. This change order is issued pursuant to (Specify Authority): 27 DCMR, Chapter 36, Section 3603 The changes set forth in Item 14 are made in the contract/order no. in item 10A.						
	B. The above numbered contract/order is modified to reflect the administrative changes (such as changes in paying office, appropriation data etc.) set forth in item 14, pursuant to the authority of						
	C. This supplemental agreement is entered into pursuant to authority of:						
	D. Other (Specify type of modification and authority)						
E. IMPORTANT: Contractor <input type="checkbox"/> is not <input checked="" type="checkbox"/> is required to sign this document and return 2 copies to the issuing office.							
14. Description of Amendment/Modification (Organized by UCF Section headings, including solicitation/contract subject matter where feasible)							
<p>Pursuant to Article 3, Changes Clause of the General Provisions (Construction Contract), Government of the District of Columbia Standard Contract Provisions For Use With Specifications for District of Columbia Construction Projects January 2007, the subject solicitation is hereby amended as follows:</p> <p>1. Listed below is the response to questions that was submitted to the Office of Contracting and Procurement in writing as Request for Information (RFI) Q1 through Q6.</p>							
Except as provided herein, all terms and conditions of the document is referenced in Item 9A or 10A remain unchanged and in full force and effect.							
15A. Name and Title of Signer (Type or print)				16A. Name of Contracting Officer			
				Diane Wooden			
15B. Name of Contractor		15C. Date Signed		16B. District of Columbia		16C. Date Signed	
						4/21/08	
<small>(Signature of person authorized to sign)</small>				<small>(Signature of Contracting Officer)</small>			

(Continuation)

Contract Number	Amendment/Modification No	Effective Date	Page of Pages
DCFB-2008-B-0037	DCFB-2007-B-0037-002	April 21, 2008	2 of 3

14. Description of Amendment/Modification (Organized by UCF Section headings, including solicitation/contract subject matter where feasible).

RFI Q1

Question:

1. The beds and bunk room furnishings appear to be N.I.C. per the drawings. Q1) Are the plastic laminate wall-mounted headboards (see section detail 6/A8.1) part of the base contract or are they N.I.C. also?

Response:

1. The plastic laminate headboards are not part of this contract.

RFI Q2

Question:

2. Reference to the lavatory cabinet section (8/A8.1) is found in the following rooms: 203, 207, 210, 215, 218. Q2) The elevations and plans at 210 and 218 show a conflict between wall-hung lavatory units and plastic laminate base cabinets with plastic laminate counters--please verify which is intended at these two locations?

Response:

2. Delete any reference to wall hung sinks, all sinks to be provided with counter bases as per detail 8/A8.1.

RFI Q3

Question:

3. Shelf and rod notes throughout the plans vary from location to location indicating metal shelving, stainless steel shelving, and wire shelves--yet I find only elevation 14/A8.1 and detail section 5/A8.2 which reference the Shop shelving (noted on A1.1 as 18"depth metal storage shelves, secured to wall, but shown in detail as hardwood banded plywood shelving on heavy duty metal standards and brackets). Q3) Could you address the issue in regard to the shelf & rod locations and typical storage shelving details such as Janitor Closets 105 & 208, Med. Storage 112, Storage 219?

Response:

3. a. Jan Closet 105, no shelves required
b. Jan Closet 208, provide shelves as per detail 5/A8.2
c. Med Storage 112, provide shelves as per detail 5/A8.2
d. Storage 219, provide shelves as per detail 5/A8.2

(Continuation)

Contract Number	Amendment/Modification No	Effective Date	Page of Pages
DCAM-2007-B-0037	DCAM-2007-B-0037-003	April 21, 2008	3 of 3

14. Description of Amendment/Modification (Organized by UCF Section headings, including solicitation/contract subject matter where feasible).

RFI Q4

Question:

4. The replacement window specification seems to limit the window manufacturer to Kolbe & Kolbe ("Heritage" line window). Q4) Can other comparable light commercial rated window manufacturers be submitted as equals (such as Marvin or Jeld-Wen)--provided they meet the performance specifications?

Response:

4. No, Kolbe and Kolbe windows has previous approval from DC Office of Historic Preservation.

RFI Q5

Question:

5. As mentioned in Drg. D1.1 / 1 – Basement Floor Plan, Keyed demolition note 11: Remove existing concrete slab for new slab but in Drg A1.1 / 2 – Basement floor plan does not mentioned indicate new concrete slab on grade. Q5) Please clarify if contractor is required to remove existing concrete at Basement Floor. If Contractor is required to remove existing concrete slab then please clarify the thickness of concrete slab on grad & provide steel details.

Response:

5. Contractor is not required to remove existing slab for the Basement floor. Demolition note # 11 is not applicable to the Basement Plan and is only applicable to the First Floor Demolition Plan.

RFI Q6

Question:

6. As mentioned in Drg. A2.1 – PROVIDE ALTERNATIVE PRICE FOR CLEANING & REPAIRING @ ALL EXIST. MASONRY, SEE SPECIFICATIONS, DIVISION 4 but no alternate price line is given on B.5 PRICE BREAKDOWN FORM. Q6) Please clarify where we can provide alternate price for cleaning & repairing @ all exist. Masonary.

Response:

6. Delete the note from Drawing A2.1. Include the cost of cleaning and repairing all existing Masonry including tuck pointing the entire exterior Masonry wall at all visible surfaces in the Base Bid.