

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. Contract Number DCFB-2009-B-0039	Page of Pages 1 1	
2. Amendment/Modification Number DCFB-2009-B-0039-0001		3. Effective Date 6/19/2009		4. Requisition/Purchase Request No.	
5. Solicitation Caption Green Roof and Roof Replacement at Engine Company No. 6 and 30					
6. Issued By: Office of Property Management (OPM) Contracting and Procurement 2000 - 14th Street, NW, 5th Floor Washington, DC 20009			7. Administered By (If other than line 6) Code _____		
8. Name and Address of Contractor (No. Street, city, country, state and ZIP Code)				(X)	9A. Amendment of Solicitation No.
					9B. Dated (See Item 11)
					10A. Modification of Contract/Order No. DCFB-2009-B-0039
					10B. Dated (See Item 13) 12-Jun-09
Code _____		Facility _____			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS					
<input type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers _____ is extended. <input checked="" type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning <u>2</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or fax which includes a reference to the solicitation and amendment number. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or fax, provided each letter or telegram makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. Accounting and Appropriation Data (If Required)					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14					
(X)	A. This change order is issued pursuant to: (Specify Authority) The changes set forth in Item 14 are made in the contract/order no. in item 10A.				
	B. The above numbered contract/order is modified to reflect the administrative changes (such as changes in paying office, appropriation date, etc.) set forth in item 14, pursuant to the authority of 27 DCMR, Chapter 36, Section 3601.2.				
	C. This supplemental agreement is entered into pursuant to authority of:				
x	D. Other (Specify type of modification and authority) Exercise of Option Year 1 - 27 DCMR, Chapter 20, Section 2008				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input checked="" type="checkbox"/> is required to sign this document and return <u>2</u> copies to the issuing office.					
14. Description of amendment/modification (Organized by UCF Section headings, including solicitation/contract subject matter where feasible.)					
A. Questions and Answers - (Attachment A).					
B. The date and time for receipt of bids remain the same. (June 26, 2009 at 2:00 P.M.)					
Except as provided herein, all terms and conditions of the document referenced in Item (9A or 10A) remain unchanged and in full force and effect					
15A. Name and Title of Signer (Type or print)			16A. Name of Contracting Officer Diane Wooden		
15B. Name of Contractor		15C. Date Signed		16B. District of Columbia	
				16C. Date Signed 6/22/2009	
(Signature of person authorized to sign)			(Signature of Contracting Officer)		

Questions and Answers
for
Green Roof and Roof Replacement at Engine Company No. 6 & 30
Solicitation Number DCFB-2009-B-0039

Question

1. *Engine Company No. 30: Drawing A1.1 shows two sets of steps from the main roof to the side roofs plus one set in the back of one lower roof. No details were provided for these steps; therefore, please clarify if they are part of the scope of work.*

Answer: The steps on the drawings are existing.

2. *Engine Company No. 6: Drawing A2.1, Detail 5 shows an irrigation system. No detail specifications were provided for the irrigation system; therefore, please verify if it is part of the scope of work for both roofs.*

Answer: Irrigation is not required. Any reference to an irrigation system on the drawings and specifications for both Engine Company #6 and #30 are to be disregarded.

3. *Please specify if the walkway pavers are to be on pedestals, and if so, provide detail and specifications for the pedestals.*

Answer: There is no requirement for pedestals under the walkway pavers.