

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. Contract Number	Page of Pages 1 1	
2. Amendment/Modification Number DCFB-2011-B-0160-002		3. Effective Date 26-Jul-11	4. Requisition/Purchase Request No.	5. Solicitation Caption Replacement of Windows at Engine Companies 7 & 30	
6. Issued By: Department of Real Estate Services Contracting and Procurement Division 2000 14th Street N.W., Suite 500 Washington, D.C. 20009		Code 03B	7. Administered By (If other than line 6) Department of Real Estate Services Contracting and Procurement Division 2000 14th Street N.W., Suite 500 Washington, D.C. 20009		
8. Name and Address of Contractor (No. Street, city, country, state and ZIP Code)			(X)	9A. Amendment of Solicitation No. DCFB-2011-B-0160	
				9B. Dated (See Item 11) 5-Jul-11	
				10A. Modification of Contract/Order No.	
				10B. Dated (See Item 13)	
Code	Facility				
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS					
<input type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended. <input type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning <u>2</u> copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or fax which includes a reference to the solicitation and amendment number. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or fax, provided each letter or telegram makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. Accounting and Appropriation Data (If Required)					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14					
(X)	A. This change order is issued pursuant to: (Specify Authority) The changes set forth in Item 14 are made in the contract/order no. in item 10A.				
	B. The above numbered contract/order is modified to reflect the administrative changes (such as changes in paying office, appropriation data, etc.) set forth in item 14, pursuant to the authority of 27 DCMR, Chapter 36, Section 3601.2.				
	C. This supplemental agreement is entered into pursuant to authority of:				
	D. Other (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input checked="" type="checkbox"/> is required to sign this document and return <u>1</u> copy to the issuing office.					
14. Description of amendment/modification (Organized by UCF Section headings, including solicitation/contract subject matter where feasible.)					
1. Response to bidder questions is attached. (Attachment A)					
2. The bid opening date is hereby extended from "July 27, 2011" by 2:00 p.m. to "August 3, 2011" by 2:00 p.m. local time.					
All other terms and conditions remain the same.					
Except as provided herein, all terms and conditions of the document referenced in Item (9A or 10A) remain unchanged and in full force and effect					
15A. Name and Title of Signer (Type or print)			16A. Name of Contracting Officer		
			Diane Wooden		
15B. Name of Contractor		15C. Date Signed	16B. District of Columbia		16C. Date Signed
(Signature of person authorized to sign)					7/26/2011
			(Signature of Contracting Officer)		

Questions and Answers

Q. We would like to have the scope of work clarified. There is mention of glass block replacement in the bid documents, but there is no specification for such. There is a specification for curtainwall (beside the window spec). We need clarification on what the owner wants. Several possibilities exist.

A. **There is no mention of glass block in the specifications and there clearly is no reference to them in the documents except demo. The new curtainwall specifications were published and there is a specification for the windows. The glazing is shown on the drawings and in the specifications.**

Q. Will the mockup be required before placement of the window order or is it the intention to install the 1st window on the regular delivery for approval of product and installation?

A. **That is required in the specifications.**

Suggestions

1. The glass block could remain and the steel window below could be removed and replaced with a new aluminum window.

Not as designed clearly on the drawings.

2. The glass block could be removed and replaced with new glass block and a new aluminum window below.

Not as designed clearly on the drawings.

3. The glass block and steel window could be removed and curtainwall could be installed in the large opening (approx 12' X 20').

Not as designed clearly on the drawings.