




<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>			1. Contract Number	Page of Pages 1 of 6	
2. Amendment/Modification Number <b>Amendment No. 2</b>		3. Effective Date See Block 16c	4. Requisition/Purchase Request No.		5. Solicitation Caption: FY 10 Citywide Federal Aid Pavement and Sidewalk Restoration (ARRA funded)
6. Issued By: Department of Transportation Office of Contracting and Procurement 2000 14th Street, N.W. 6th Floor Washington, D.C. 20009			7. Administered By (If other than line 6) Procurement Support Branch 2000 14th Street, N.W. 3rd Floor Bid Room Washington, D.C. 20009		
8. Name and Address of Contractor (No. Street, city, country, state and ZIP Code)			<input checked="" type="checkbox"/> 9A. Amendment of Solicitation No. <b>DCKA-2010-B-0106</b>	<input type="checkbox"/> 9B. Dated (See Item 11) 2/4/2010	
Code			Facility	10A. Modification of Contract/Order No.	
				10B. Dated (See Item 13)	
<b>11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS</b>					
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended. <input checked="" type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or fax which includes a reference to the solicitation and amendment number. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or fax, provided each letter or telegram makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. Accounting and Appropriation Data (If Required)					
<b>13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14</b>					
A. This change order is issued pursuant to: (Specify Authority) The changes set forth in item 14 are made in the contract/order no. in item 10A.					
B. The above numbered contract/order is modified to reflect the administrative changes (such as changes in paying office, appropriation date, etc.) set forth in item 14, pursuant to the authority of 27 DCMR, Chapter 36, Section 3601.2.					
C. This supplemental agreement is entered into pursuant to authority of:					
D. Other (Specify type of modification and authority)					
<b>E. IMPORTANT:</b> Contractor <input type="checkbox"/> is not, <input checked="" type="checkbox"/> is required to sign this document and return <u>1</u> copies to the issuing office.					
14. Description of amendment/modification (Organized by UCF Section headings, including solicitation/contract subject matter where feasible.) <b>This solicitation for FY 10 Citywide Federal Aid Pavement/Sidewalk Restoration is subject to American Recovery and Reinvestment Act (stimulus) reporting requirements. The Bid Opening Date of February 26, 2010 is not extended</b> <b>This amendment is issued to clarify the following:</b>					
<p>1. Line No. 0340 Replace Existing Basin with Water Quality Basin ( Item No. 311991- Special Item) Water Quality Catch Basin details attached (6 pages)</p> <p>2. SP 42 Emergency Mobilization- Measure of Payment shall read: "The Unit of measure for Emergency Mobilization will be LUMP SUM"</p> <p>3. Line No. 0760 PCC Median Barrier (Item No. 614002) The barriers are temporary as described in SP 614.02(A) of the Standard Specifications for Highways and Structures, 2009</p> <p>4. SP 51 Insurance issued under Amendment No. 1 remains unchanged.</p> <p style="text-align: center;"><b>No further questions will accepted per issuance of this amendment.</b></p>					
Except as provided herein, all terms and conditions of the document referenced in Item (9A or 10A) remain unchanged and in full force and effect					
15A. Name and Title of Signer (Type or print)			16A. Name of Contracting Officer Jerry M. Carter		
15B. Name of Contractor		15C. Date Signed	16B. District of Columbia Jerry M. Carter		16C. Date Signed 2/23/10
(Signature of person authorized to sign)			(Signature of Contracting Officer)		



SECTION A - A  
CATCH BASIN TOP  
STD. DET. S/30.11  
CATCH BASIN BODY





VIEW C-C

- NOTES:
1. ALL CONCRETE TO BE CLASS 4000, AIR ENTRAINED, TYPE II CEMENT.
  2. REINFORCING STEEL SHALL CONFORM TO ASTM A615, GRADE 60.

APPROVED DATE: \_\_\_\_\_  
DIRECTOR, DEPARTMENT OF ENGINEERING  
AND TECHNICAL SERVICES

REVISION NO.: \_\_\_\_\_  
DATE: 8-16-07  
PREPARED BY: W. DEVALGHAN  
CHECKED BY: \_\_\_\_\_


STANDARD DETAIL  
DUAL THROAT  
WATER QUALITY BASIN




APPROVED DATE: \_\_\_\_\_  
 \_\_\_\_\_  
 DIRECTOR, DEPARTMENT OF ENGINEERING  
 AND TECHNICAL SERVICES

REVISION NO.: \_\_\_\_\_  
 DATE: 8-18-07  
 PREPARED BY: W. DEVAUGHN  
 CHECKED BY: \_\_\_\_\_

STANDARD DETAIL  
 DUAL THROAT  
 WATER QUALITY BASIN



VIEW D-D



VIEW E-E

APPROVED DATE: \_\_\_\_\_

DIRECTOR, DEPARTMENT OF ENGINEERING  
AND TECHNICAL SERVICES



REVISION NO.: \_\_\_\_\_

DATE: 8-16-07


PREPARED BY: W. DEVAUGHN

CHECKED BY: \_\_\_\_\_

STANDARD DETAIL  
DUAL THROAT  
WATER QUALITY BASIN



SECTION A-A





VIEW C-C

- NOTES:
1. ALL CONCRETE TO BE CLASS 4000, AIR ENTRAINED, TYPE II CEMENT.
  2. REINFORCING STEEL SHALL CONFORM TO ASTM A615, GRADE 60.

APPROVED DATE: MAY 00, 200X  
 DIRECTOR, DEPARTMENT OF ENGINEERING AND TECHNICAL SERVICES

REVISION NO.: 0  
 DATE: 5/00/0X  
 PREPARED BY: I. SMITH  
 CHECKED BY: W.DARROW

STANDARD DETAIL  
 SINGLE THROAT  
 WATER QUALITY BASIN




APPROVED DATE: MAY 00, 200X


DIRECTOR, DEPARTMENT OF ENGINEERING  
AND TECHNICAL SERVICES

REVISION NO.: 0  
DATE: 5/00/200X  
PREPARED BY: I. SMITH  
CHECKED BY: W. DARROW

STANDARD DETAIL  
SINGLE THROAT  
WATER QUALITY BASIN



VIEW D-D



VIEW E-E

APPROVED DATE: MAY 00, 200X

DIRECTOR, DEPARTMENT OF ENGINEERING  
 AND TECHNICAL SERVICES

REVISION NO.: 0  
 DATE: 5/00/200X  
 PREPARED BY: J. SMITH  
 CHECKED BY: W. DARROW

STANDARD DETAIL  
 SINGLE THROAT  
 WATER QUALITY BASIN