


AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. Contract Number DCKA-2010-B-0166	Page of Pages 1 4
2. Amendment/Modification Number 6	3. Effective Date See 16C	4. Requisition/Purchase Request No.		5. Solicitation Caption Rehabilitation of Columbus Plaza, NE
6. Issued By: Department of Transportation Office of Contracting and Procurement 2000 14th Street, NW 6th Floor Washington, DC 20009		Code	7. Administered By (If other than line 6) Department of Public Works Office of Contracting and Procurement Reeves Center, 3rd Floor 2000 14th Street, NW Washington, DC 20009	
8. Name and Address of Contractor (No. Street, city, country, state and ZIP Code)			(X)	9A. Amendment of Solicitation No. DCKA-2010-B-0166
				9B. Dated (See Item 11)
				10A. Modification of Contract/Order No.
				10B. Dated (See Item 13)
Code	Facility			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS				
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended. <input checked="" type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or fax which includes a reference to the solicitation and amendment number. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or fax, provided each letter or telegram makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
12. Accounting and Appropriation Data (If Required)				
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14				
A. This change order is issued pursuant to: (Specify Authority)				
The changes set forth in Item 14 are made in the contract/order no. in item 10A.				
B. The above numbered contract/order is modified to reflect the administrative changes (such as changes in paying office, appropriation date, etc.) set forth in item 14, pursuant to the authority of 27 DCMR, Chapter 36, Section 3601.2.				
C. This supplemental agreement is entered into pursuant to authority of:				
D. Other (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input checked="" type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.				
14. Description of amendment/modification (Organized by UCF Section headings, including solicitation/contract subject matter where feasible.) A CONTRACT AMENDMENT IS NECESSARY TO MODIFY SPECIAL PROVISIONS (SP) AND OTHER ITEMS OF THE SOLICITATION AS FOLLOWS:				
<u>RESPONSES TO RFI</u>				
PLEASE SEE ATTACHED RESPONSES TO RFI S SUBMITTED BY CAPITOL PAVING OF DC, INC., FORT MYER CONSTRUCTION CORP. AND RUSTLER CONSTRUCTION CO., INC.				
Except as provided herein, all terms and conditions of the document referenced in Item (9A or 10A) remain unchanged and in full force and effect				
15A. Name and Title of Signer (Type or print)			16A. Name of Contracting Officer Jerry M. Carter	
15B. Name of Contractor		15C. Date Signed	16B. District of Columbia	16C. Date Signed
(Signature of person authorized to sign)			 (Signature of Contracting Officer)	12/28/10

Amendment of Solicitation/Modification of Contract
AMENDMENT NO. 6
CURRENT BID OPENING DATE: January 5, 2011

Contract No.: DCKA-2010-B-0166
Caption: Rehabilitation of Columbus Plaza, NE

RESPONSES TO REQUESTS FOR INFORMATION (RFIs):

Fort Myer Construction (December 20, 2010)

1. Please provide type for the following light poles:
 - a. L28(sheet 130/172) – **Response:** L28 is a twin-20 pole.
 - b. L07A-US, L03A and L03B(sheet 144/172) – **Response:** *these are twin-20 poles.*
2. Sheet 127/172(NPS electrical work) asks for removal of existing cables and repairs of existing manholes.
 - a. Is PEPCO the owner of existing manholes and/or cables from NPS property?
- **Response:** *yes*
 - b. Is a PEPCO authorized contractor allowed to remove PEPCO cables?–
Response: *Normally that is the standard practice.*
3. On USRC portion of work, does Twin-20 pole fits over security bollard or in between security bollards? – **Response:** *in between.*
4. C.53 ENGINEER'S FIELD FACILITIES, states that the contractor shall furnish and maintain one six (6) cylinder four wheel drive, fueled at all times, which passes the D.C. Motor Vehicle Inspection, for the use of the engineer or other District representatives for the duration of the project. This requirement is contrary to the current DDOT policy? **Response:** *No it is not.*
5. With regards to the requirement found on page 165 of the solicitation, that the “contractor shall employ a full time public relation officer...” we have a series of questions as mentioned previously:

Should the contractor’s bid contain a maximum, minimum or specific amount of compensation or payment for the position of public relations officer?

Response: *This is a job with average salary that will be approved by DDOT.*

Will the contractor supervise the work of the individual?

Response: *No, DDOT will. The person will report to Program Manager directly and will work with full coordination with DDOT PR office.*

To whom will this individual report on a daily basis?

Response: *To DDOT*

Is it expected that the contractor shall recruit, interview and hire this individual?

Response: Contractor & DDOT, but DDOT has the final approval

May this individual be an existing employee of the contractor or must this position be a new hire or consultant?

Response: *New Hire*

Should this position be included in the certified payroll for the project?

Response: *Yes*

Capitol Paving of DC, Inc. (December 27, 2010)

1. On page 158 of Specification section C.47.7 for Security Bollards, the payment for concrete paving for these bollards shall be paid under Item 608005. The same pay item is also mentioned for the Removable Bollards and Security Bollards on Shallow Foundations on page 160 & 165 of Specification Section C.48.6 & C.51.12 where concrete paving will be paid under item 608005. Upon checking the schedule of items, I cannot find this pay item. Is this an additional pay item?

Response: *Item No. 608 005, which is Special item No. 608 992 and CLIN No. 0820 is included in the Schedule of Items on Page 12 and description on Page 150 under Section C.43.*

2. On page 164 of Specification Section C.51.12 it states that the measurement of Security Bollards for Shallow Foundation shall on a Lump Sum basis. Is it not that the unit of payment for security bollards is per EACH item as mention on item 000506 on page 3? **Response:** *This applies in the areas where the existing sidewalk concrete is to remain.*

Rustler Construction Inc. (December 22, 2010)

1. What are the specific concerns of the National Park Service (NPS) regarding the fountains and monument? We need direction from NPS regarding the monitoring they are looking for: what kind they will insist on, what level of monitoring, how often or how soon they are notified of exceeding the allowable criteria.

a. Is the NPS concerned about the mortar loss between the stone blocks on the west side of the monument? The mineral striations that look like cracks in the stone blocks, also on the west side?

2. If the concerns are the vibrations generated by the construction, what levels will be acceptable?

3. The item for Progress Photos includes 20 pre-construction photos, 10 of which are in the fountain/monument area. This quantity would not adequately document pre-construction (existing) conditions. Should there be an item for pre-construction surveys of the site without a limitation on the number of photos? It will be difficult, at best, to prove that the construction caused or didn't cause damage to the NPS monument or fountains with only 10 photos.

4. Tiltmeters? Where?

5. Crack monitoring? Where?

***RESPONSE:** The NPS completed a full condition assessment of the Columbus Memorial and fountains in 2010, "Columbus Memorial, Plaza and Fountains: Investigative Condition Assessment and Report" by Oehrlein & Associates Architects, which can be provided to the selected contractor. This report included vibration monitoring at the site, with four monitors on the Columbus fountain and one monitor on the granite bowl fountain. The existing conditions of these structures are well documented, including cracks, open joints, areas of settlement, etc. The NPS representatives will work with the contractor to identify the areas of concern and apply monitors for the duration of construction, which will be observed for signs of additional damage or structural instability. (In particular at the eagle wings and cornice of the Columbus fountain.) Any signs of damage to historic structures should be reported to the NPS immediately and this will be a stipulation of the construction permit issued by the NPS for this project on NPS property. The contractor is welcome to offer more progress photos to document before/after conditions; however, the NPS report does adequately document conditions in 2010.*