


<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>			1. Contract Number <b>DCKA-2010-B-0195</b>	Page of Pages 1   17
2. Amendment/Modification Number <b>8</b>	3. Effective Date <b>See 16C</b>	4. Requisition/Purchase Request No.		5. Solicitation Caption <b>Rehab of K St., Mass Ave and H St Bri</b>
6. Issued By: <b>Department of Transportation Office of Contracting and Procurement 2000 14th Street, NW 6th Floor Washington, DC 20009</b>		Code	7. Administered By (If other than line 6) <b>Department of Public Works Office of Contracting and Procurement Reeves Center, 3rd Floor 2000 14th Street, NW Washington, DC 20009</b>	
8. Name and Address of Contractor (No. Street, city, country, state and ZIP Code)			(X) 9A. Amendment of Solicitation No. <b>DCKA-2010-B-0195</b>	9B. Dated (See Item 11)
Code			10A. Modification of Contract/Order No.	
Facility			10B. Dated (See Item 13)	
<b>11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS</b>				
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input checked="" type="checkbox"/> is extended. <input type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or fax which includes a reference to the solicitation and amendment number. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or fax, provided each letter or telegram makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
<b>12. Accounting and Appropriation Data (If Required)</b>				
<b>13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14</b>				
A. This change order is issued pursuant to: (Specify Authority)				
The changes set forth in Item 14 are made in the contract/order no. in item 10A.				
B. The above numbered contract/order is modified to reflect the administrative changes (such as changes in paying office, appropriation date, etc.) set forth in item 14, pursuant to the authority of 27 DCMR, Chapter 36, Section 3601.2.				
C. This supplemental agreement is entered into pursuant to authority of:				
D. Other (Specify type of modification and authority)				
<b>E. IMPORTANT:</b> Contractor <input checked="" type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.				
<b>14. Description of amendment/modification (Organized by UCF Section headings, including solicitation/contract subject matter where feasible.)</b> <b>A CONTRACT AMENDMENT IS NECESSARY TO MODIFY SPECIAL PROVISIONS (SP) AND OTHER ITEMS OF THE SOLICITATION AS FOLLOWS:</b> <u><b>BID OPENING DATE EXTENSION</b></u> The bid opening date has been extended to Wednesday, May 25, 2011. The time and location is unchanged.  <u><b>WAGE RATES</b></u> DELETE General Wage Decision DC01000001, 01/21/2011, DC1, Modification No. 13 dated 01/21/2011 and REPLACE with the attached General Wage Decision DC1000001 05/06.2011 DC1, Modification No. 15 dated 05/06/2011.  <u><b>CUTOFF FOR REQUESTS FOR INFORMATION</b></u> THE DEPARTMENT WILL NOT ACCEPT ANY REQUESTS FOR INFORMATION/CLARIFICATION AFTER COB FRIDAY, MAY 13, 2011.  <u><b>RFI RESPONSES</b></u>  <b>SEE ATTACHED.</b>				
Except as provided herein, all terms and conditions of the document referenced in Item (9A or 10A) remain unchanged and in full force and effect				
15A. Name and Title of Signer (Type or print)			16A. Name of Contracting Officer Jerry M. Carter	
15B. Name of Contractor		15C. Date Signed	16B. District of Columbia	16C. Date Signed
(Signature of person authorized to sign)				5/12/11
			(Signature of Contracting Officer)	

# Amendment of Solicitation/Modification of Contract

## AMENDMENT NO. 8

Contract No.: *DCKA-2010-B-0195*

**Caption: *Rehabilitation of K Street, Massachusetts Avenue and H Street Bridges over Center Leg Freeway and Electrical-Mechanical Upgrade of the Air-Rights Tunnel***

### Pre - Bid Questions

#### **Mechanical:**

1. Will DDOT allow the contractor to submit Partial Payments on Lump Sum Pay Items as work progresses and for new equipment that is on-site or stored within?

**Response: Yes, based on the progress made in the field.**

2. Are the existing Vibration Isolators under existing fans receiving new motors to be replaced with new?

**Response: No unless, require replacement due to new motors.**

3. Mechanical Demolition Note 3 states "PROVIDE "DUMPSTER" (APPROPRIATELY LABELED AND CLEAN-UP AND REMOVE ALL TRASH, TREES, ETC. FROM SITE." Since the note is shown on the South Exhaust Tower, is the word "SITE " applicable only to the south Exhaust Tower? If not, what are the limits of the site?

**Response: It meant site necessary for demolition work at all locations. As stipulated in notes 18, 21 and 25 on Drawing. M-01.**

4. Many of the Reference Drawings show the As-Built conditions based on when the tunnel and towers were constructed. Do the contract documents reflect the actual changes and improvements that have occurred since the tunnel was constructed? IF not, please providers with drawings which indicate all the renovations, updates, and modifications in the mechanical and electrical systems that have occurred. **Response: Drawings available to designer were provided as reference drawings and may not reflect changes occurred since the tunnel was constructed. The Contractor needs to check field conditions to determine as-built conditions.**

5. Demolition Notes 9 and 10 on Drawing. M-06 and M-20 calls for the removal of portions the existing tees and ceiling panels as required for the installation of electrical, plumbing, and mechanical work, and the replacement of damaged tees and acoustical panels. How are the ceiling panels connected to the tees?

**Response: Ceiling panels are bolted to the tees.**

6. What is the square footage of tile to be replaced in the Electrical and Control Room?

**Response: Refer to Drawing M-06, Part Plan - Structural Notes. The plan shows area of the work. Only damaged tiles need to be replaced. The Contractor shall make assumptions and check field conditions to determine square footage.**

7. The drawings indicate that the CO Monitoring System is not in use. The specifications requires the contractor to verify that the CO System is operating on a daily basis and calibrated annually. How does the contractor perform maintenance on a system that is Not in Use?

**Response: The CO Monitoring System is an existing functioning system that has been recently upgraded to MSA Multiguard 8. The specification requires that the Contactor connects the existing CO sensor to new PLC.**

8. Has DDOT performed an analysis of the materials being demolished for asbestos contamination? How does the contractor know if the materials contain asbestos? Will there be an allowance for Asbestos Abatement?

**Response: Asbestos Abatement Report is included in the contract documents.**

**Electrical:**

9. What is the maximum allowable or acceptable distance for wiring from the VFD to the fan motor, which will not be detrimental to the operation of the VFD?

**Response: There is no limit. Supplier of the VFD will provide filtering equipment on output side of the VFD and advise based upon his analysis if the special cable with shield is needed when distance is more than the rule of thumbs used by the designers to go with a regular cable when distance between the VFD and more is less than 250'. We have provided VFD specification, which clearly indicate that**

**the supplier of the VFD needs to provide filtering equipment to eliminate the concern of this maximum distance. Contractor need to take recommendation of the supplier of the VFD on this concern. We do not see any concern so long the VFD supplier supplies proper filtering equipment dv/dt filters or their specific design. Please note each VFD supplier will have their own solutions. The Contactor needs to resolve this technical concern before accepting the supplier of the VFD equipment.**

10. Under what circumstances would the contractor be advised to use of Item 618991 "CONTINGENT VFD TYPE CABLE?" There must be a reason the Owner chose to add this bid item.

**Response: See response to Item 9 above.**

11. Drawing E-28 has a notation (top center of the drawing) at the #2 service conduit entry point: "PROVIDE 4-4" SLEEVE." Can we get some additional information and a detail sketch of what the Owner is requesting of the contractor? What is on the other side of the wall?

**Response: The existing #2 Service has 2-4" conduits, not six shown on DWG. E-28. Four additional conduit sleeves are required for the upgraded Service #2. For location of existing Pepco Manhole see DWG. E-31.**

12. Are the manholes associated with the North Exhaust Tower duct bank accessible to the contractor to pull out/in cable? Where are they located?

**Response: Drawing E-31 shows the location of the existing MH. These MH should be accessible as currently existing cables are in operation.**

13. What type of repairs to the tunnel ceiling tiles is required after the removal of the existing light fixtures?

**Response: Remove anchors, patch holes and clean the ceiling tile. See Specification Section 16035.**

14. Drawing E-09 identifies the disconnects for the fans as 400A, 3p non-fusible switches. Drawing E-22 and E-24 identifies these as NEMA 12, 3p/400/600V. Which is correct?

**Response: Correct disconnect shall be rated at NEMA 12, 3-Pole/400A/600V, non-fusible.**

15. The Scope of Work in the specifications, Page 69 Item #67 indicates new smoke detectors and new heat detectors are shown on various drawings. They are not shown on the indicated drawings. Are they to only tie into the mechanical control system and not report to a fire alarm system? Please advise how we are to proceed.

**Response: Drawing E-27 shows three (3) smoke detectors by symbol S and wiring to PLC. In addition this drawing shows final home run wiring coming from tunnel Linear Heat Detector (LHD) shown on M-08, M-09 and M-20.**

16. The Scope of work on Page 110 indicates electrical maintenance to be performed. Please provide the following information as quantities are not available on the drawings nor in specifications:
- How many CCTV cameras to be aligned? **24 EA**
  - How many emergency telephones to be tested? **42 EA**
  - How many existing MCC's, panelboards, transformers, and switch boards are to be infrared scanned? **16 EA**

17. Drawing SL 10 shows vaults EV-1 Through EV-7 with a note to see structural drawings. The sizes of these vaults are not shown on the structural drawings. Please advise the sizes.

**Response: E-1 through EV-7 will be installed on the bridge in the sidewalk. The Handholes shall be 24"X18"X12".**

Civil:

18. Drawing S-32 shows partial elevation of closure wall with different heights. We need a layout of the closure wall showing the length and height of the wall at various locations to estimate the quantities.

**Response: Drawing S-32 depicts a schematic elevation of the closure wall showing various beams, girders, and utilities spanning over the tunnel. The actual height of the wall varies along the tunnel. For bidding purposes the Contractor shall make an assumption on the average wall height based on the field observations purposes.**

19. In the Schedule of Items, Items 1750, 1760, 1770 and 1780 specify two different thicknesses of spall repairs for each item. As an example description of Item 1750 is "Repair-Replace PCC Substructure (two inches or less in depth) CONCRETE REPAIR TYPE 2 (SPALL LESS THAN 4".) Please clarify which depth of repairs apply to either item.

**Response:** The correct Items affected by this question are 1740, 1750, 1760, and 1770. Items 1740 and 1750 are for Spall Repairs of 4" or less (see Type 2 Repair on Dwg. S-27) and Items 1760 and 1770 are for Spall Repairs greater than 4" (see Type 1 Repair on Dwg. S-27).

20. In S.P. 95 the minimum thickness of the each coat of epoxy coating is specified at 5 mm which adds up to 10 mm equal to 0.4 Inch. This is a very thick coating which cannot be achieved by roller or brush application without sagging. Please confirm that the specified thickness is correct, otherwise, provide the thickness.

**Response:** The first coating shall have a min. 2 mm thickness and the second coating shall have a min. 3 mm thickness, with the total thickness being min. 5 mm.

### **Electrical**

Item 618498 Are the Eighteen - #16 Aluminum Poles furnished by the District of Columbia being supplied complete with casings drilled for photo controls? Will the poles be painted black? What arrangements must the contractor make to receive these poles?

**Response:** Item 618498 Install D.C. Furnished #16 Aluminum Pole shall be revised to read: Item 618486 Furnish and Install #16 Cast Iron Pole.

Is Item 618754 referring to the furnishing of 18 –GE Streetdreams Post Top, Prismatic Series, or approved equal AND 12 – GE Streetdreams Post Top, Avery Series, or approved equal? Are these Post Top Luminaires the cut off design described on Line Number 1110?

**Response:** All Luminaries on #16 Poles are to be full cut off design.

Does Item 617040 also include the transfer of the existing traffic signal controller to the temporary portable concrete base?

**Response:** No, it does not include transferring the existing controller to the temporary portable concrete base.

### **Structural**

The Specification and the General Notes on the drawings directs the Bidders to make measurements and observations that are not possible in a single two hour pre-bid walk through, will an additional walkthrough be scheduled? **Response:** NO, There is no additional walkthrough scheduled.

Item 609200, PCC Wheelchair/Bicycle Ramp includes detectable warning pavers. Additionally item 600014 is for detectable warning surface. Please clarify whether this is a duplication or the two Items are different and for different locations. **Response: Item 609200 is for standard PCC Wheelchair/Bicycle Ramps and it includes detectable warning pavers. Item 600014 is for the ramp through the median on Massachusetts Ave. with detectable warning pavers.**

The scope for Item 205008, Demolition, includes provision of protection shield as necessary. The SCHEDULE OF ITEMS includes Item 626002 for protection shield. Please inform whether protection shield will be paid separately or as part of demolition item. **Response: The Protection Shield will be paid for under separate item.**

Could you please provide details of the ceiling panels to be replaced? Without such details it is impossible to price it. **Response: According to existing plans, the panels are 14 gage ceramic enamel ceiling tiles.**

With the extension of bid due date to May 10, 2011, what is the deadline for receiving RFI's? **Response: Amendment will send out to advise the cutoff date.**

**Response to RFI from Martins Construction, dated May 4, 2011**

***Question: 1.*** The Bid Documents of the referenced invitation fail to provide a hardware schedule that will give the mechanical functions of each lockset, number and size of hinges on the existing doors, type of lever handle, and type of closers (if any), for each new and existing door. It will be difficult to provide an accurate bid without knowing the aforementioned information. In order to match the existing master keying system, we will need to know the manufacturer of the existing locks and the type of master keying system that we are to match. Are the keying requirements limited to the doors and locksets indicated in the schedule on Drawing M-26 and M-27? How many pairs of hinges are on the existing doors? Which doors have continuous hinges? Spec Section 08710 – Finish Hardware Part 2 Products Paragraph 2.1 A states that “Requirements for design, grade, function, size and other distinctive qualities of each type of finish hardware are indicated below.” The function of each type of hardware is not indicated on the plans. Part 2 Products Paragraph 2.3 Paragraph C states “Provide mortise locks in the functions and types, as required.” What are the functions that are required?

***Response:*** The doors that require hardware replacement are indicated on Drawings. M-26 and M-27. Locations of the doors are shown on Reference Drawings. M-28 through M-41. We do not possess detailed information of the type of the keying system and the manufacturer of the current hardware.

**Response to RFI from Martins Construction, dated May 6, 2011**

1. Is the Street Lighting work indicated on drawings SL1 through SL13 to be priced in the lump sum totals or is it to be priced by the unit prices (Items 0950 through 1140). Please note that quantities for Items 1080 and 1090 match the quantities required by drawings and Item 1100 is one more than required by drawings.

**Response: The street lighting items are to be paid by unit prices.**

2. Please confirm PVC conduit can be used for the site lighting. There is no PVC conduit listed in the conduit specifications.

**Response: Conduit for street lighting is PVC.**

3. Bid items 1150 through 1260 are all listed as electrical works. Bid items 1280 through 1530 are all listed as mechanical works. Are items listed under mechanical (example, Item 1350- Replace 150 HP Tunnel Ventilation Fan Motors) supposed to include the electrical connections also? Please note that conduit and wire is included under Items 1190 and 1200.

**Response: The work is described in the relevant drawings and specification sections. The Contractor is responsible for completed work. It is the Contractor's responsibility to coordinate the interfacing of electrical and mechanical work.**

4. Please provide specifications for ceiling and floor tiles in Electrical and Control Room.

**Response: Only damaged ceiling panels and floor tiles in Electrical and Control Room need to be replaced. The Contractor has to match the appearance and type of the panels and tiles as closely as practically possible. We do not possess the specifications for these items.**

General Decision Number: DC100001 05/06/2011 DC1

Superseded General Decision Number: DC20080001

State: District of Columbia

Construction Types: Heavy (Heavy and Sewer and Water Line) and Highway

County: District of Columbia Statewide.

HEAVY CONSTRUCTION PROJECTS (Including Sewer and Water Lines);  
HIGHWAY CONSTRUCTION PROJECTS

Modification Number	Publication Date
0	03/12/2010
1	03/19/2010
2	04/23/2010
3	05/07/2010
4	06/11/2010
5	07/09/2010
6	07/23/2010
7	08/20/2010
8	09/24/2010
9	11/05/2010
10	12/10/2010
11	12/24/2010
12	01/07/2011
13	01/21/2011
14	04/15/2011
15	05/06/2011

ASBE0024-001 10/01/2009

	Rates	Fringes
Asbestos Worker/Heat and Frost Insulator Includes the application of all insulating materials, protective coverings, coatings and finishes to all types of mechanical systems.....	\$ 30.43	14.43

ASBE0024-002 10/01/2009

	Rates	Fringes
HAZARDOUS MATERIAL HANDLER Includes preparation, wetting, stripping, removal, scrapping, vacuuming, bagging and disposing of all insulation materials, whether they contain asbestos or not, from mechanical systems.....	\$ 18.85	7.10

ASBE0024-005 10/01/2009

	Rates	Fringes
Fire Stop Technician.....	\$ 24.10	6.94
Includes the application of materials or devices within or around penetrations and openings in all rated wall or floor		

assemblies, in order to prevent the passage of fire, smoke of other gases. The application includes all components involved in creating the rated barrier at perimeter slab edges and exterior cavities, the head of gypsum board or concrete walls, joints between rated wall or floor components, sealing of penetrating items and blank openings.

BOIL0193-001 10/01/2009

	Rates	Fringes
Boilermakers:.....	\$ 37.66	16.36

BRDC0001-001 05/03/2010

	Rates	Fringes
Bricklayer.....	\$ 27.21	7.21

BRMD0001-004 04/25/2010

	Rates	Fringes
BRICKLAYER Refractory (Firebrick).....	\$ 33.55	7.72

CARP0132-001 05/01/2010

	Rates	Fringes
Carpenter/Lather.....	\$ 26.38	7.00
Piledriver.....	\$ 24.48	7.80

CARP1831-001 04/01/2010

	Rates	Fringes
Carpenters: Millwrights.....	\$ 27.91	10.90

CARP2311-002 05/01/2009

	Rates	Fringes
DIVER TENDER.....	\$ 24.48	7.80
DIVER.....	\$ 36.13	7.80

ELEC0026-001 06/01/2010

	Rates	Fringes
Electricians.....	\$ 39.02	12.82

ELEC0026-008 07/01/2003

	Rates	Fringes
Motor Repairmen Removal and reinstallation of electrical motors.....	\$ 23.69	7.73+3%+a

a. PAID HOLIDAYS:

New Year's Day, Martin Luther King Jr.'s Birthday, Inauguration Day, Memorial Day, Fourth of July, Labor Day, Veterans Day, Thanksgiving Day, the day after Thanksgiving and Christmas Day or days designated as legal holidays by the Federal Government.

ELEC0070-001 05/04/2009

	Rates	Fringes
Line Construction:		
Cable Splicers.....	\$ 30.06	18.75%+4.75
Equipment Mechanic.....	\$ 21.82	19.75%+4.81
Equipment Operators.....	\$ 30.06	18.75%+4.75
Groundman/Truck Driver.....	\$ 15.34	19.75%+4.81
Line Truck with Auger.....	\$ 20.09	19.75%+4.81
Linemen.....	\$ 30.06	18.75%+4.75

-----  
 ENGI0077-001 05/01/2010

	Rates	Fringes
Power equipment operators: (HEAVY AND HIGHWAY CONSTRUCTION)		
GROUP 1.....	\$ 32.09	7.87+a+b
GROUP 2.....	\$ 31.09	7.87+a+b
GROUP 3.....	\$ 30.63	7.87+a
GROUP 4.....	\$ 29.92	7.87+a
GROUP 5.....	\$ 27.89	7.87+a
GROUP 6.....	\$ 23.35	7.87+a
GROUP 7.....	\$ 32.46	7.87+a

#### POWER EQUIPMENT OPERATORS CLASSIFICATIONS

GROUP 1: Tower Cranes and Cranes 100 ton and over.

GROUP 2: 35 ton cranes & above, tower & climbing cranes, derricks, concrete boom pump, drill rigs (equivalent to L & Double L), mole.

GROUP 3: Backhoes, cableways, cranes, cherry pickers, elevating graders, hoists, paving mixers, power shovels, tunnel shovels, batch plants, shields, tunnel mining machines, gradalls, front end loaders, 3 1/2 cu. yds. and above, power driven wheel scoops and scrapers (50 cu. yds. struck capacity or above), rail tamper, draglines, boomcat, mucking machines, graders in tunnels, pile driving engines.

GROUP 4: Front end loaders below 3 1/2 cu. yds, boom trucks, hydraulic backhoes 1/2 yds. capacity or below rubber or track mounted, tug boats, power driven wheel scoops & scrapers, blade graders, motor graders, bulldozers, trenching machines, concrete mixer, speed swing pettibone, ballast regulator, concrete pump, mechanic, welder, mechanic welder, shotcrete machines, Hoeram, locomotive (standard, narrow gauge), tuggers.

GROUP 5: High lifts above 10 feet, boilers (skelton), asphalt spreaders, bullfloat finishing machines, concrete finishing machines, concrete spreaders, fine graders, air compressors, welding machines, pumps, generators, well points, deep wells, hydraulic pumps, elevators, freeze uniits, tunnel motorman or dinky operator, roller, conveyors, well drilling machines, grout pump, fireman.

GROUP 6: Fork lifts, ditch witch, bobcat 1/3 cu. yd. and below, space heaters, sweepers, assistant engineers, oilers.

GROUP 7: Master mechanic.

a. PAID HOLIDAYS: New Years Day, Inaugural Day, Decoration Day, Independence Day, Labor Day, Martin Luther King's Birthday, Veterans' Day, Thanksgiving Day, Friday after Thanksgiving and Christmas Day.

b. PREMIUM PAY:

Tower crane and cranes 100-ton and over to receive \$1.00 per

hour premium over Group One.

-----  
 ENGI0077-002 06/01/2010

	Rates	Fringes
Power equipment operators: (PAVING AND INCIDENTAL GRADING)		
GROUP 1.....	\$ 25.29	6.30
GROUP 2.....	\$ 22.40	6.30
GROUP 3.....	\$ 19.24	6.30
GROUP 4.....	\$ 17.40	6.30
GROUP 5.....	\$ 25.88	6.10

POWER EQUIPMENT OPERATORS CLASSIFICATIONS

- GROUP 1: Gradall operator, Crane.
- GROUP 2: Boom Truck, Milling Machine, Excavator, Rubber Tire Backhoe, Asphalt Paver, Asphalt Plant Engineer, Motor Grader, Track Loader, Rubber Tire Loader, Track Dozer, Concrete Paver.
- GROUP 3: Broom Truck, Asphalt Roller.
- GROUP 4: Air Compressor, Grade Rollers.
- GROUP 5: Mechanic.

-----  
 ENGI0077-003 07/01/2009

	Rates	Fringes
Power equipment operators: (SEWER, GAS AND WATER LINE CONSTRUCTION)		
GROUP 1.....	\$ 22.48	6.12+a
GROUP 2.....	\$ 22.08	6.12+a
GROUP 3.....	\$ 21.57	6.12+a
GROUP 4.....	\$ 21.25	6.12+a
GROUP 5.....	\$ 20.43	6.12+a

POWER EQUIPMENT OPERATORS CLASSIFICATIONS

- GROUP 1: Excavators, Cranes, Gradalls.
- GROUP 2: Backhoes, Front-end Loaders, Fork alift/Lull, Bulldozers, Motor Graders. Qualified Mechanics, Hydraulic Tamper and Hoe Pack, Paving Mixers, Pile Driving Engines, Batch Plant, Concrete Pumps, Low-Boy Driver, Lube Truck.
- GROUP 3: Trenching Machine, Well Drilling Machines, Concrete Mixers, Motor Graders, Truck Driver.
- GROUP 4: Roller, Air Compressors, Pumps, Welding Machines, Well Points, Firemen.
- GROUP 5: Oiler

a. PAID HOLIDAYS: New Year's Day, Inaugural Day, Washington's Birthday, Decoration Day, Independence Day, Labor Day, Veterans Day, Thanksgiving Day, Christmas Day and Martin Luther King's Birthday.

-----  
 IRON0005-001 06/01/2009

	Rates	Fringes
Ironworkers:		
Structural, Ornamental and Chain Link Fence.....	\$ 28.83	13.295

-----  
 IRON0201-001 05/01/2009

	Rates	Fringes
Ironworkers:		
Reinforcing.....	\$ 25.20	14.33

---

LABO0657-003 06/01/2010

	Rates	Fringes
Laborers: (HEAVY AND HIGHWAY AND SEWER & WATER LINES CONSTRUCTION)		
GROUP 1.....	\$ 21.64	5.97
GROUP 2.....	\$ 21.98	5.97
GROUP 3.....	\$ 22.16	5.97
GROUP 4.....	\$ 22.33	5.97
GROUP 5.....	\$ 22.80	5.97
GROUP 6.....	\$ 23.39	5.97
GROUP 7.....	\$ 23.96	5.97
GROUP 8.....	\$ 24.73	5.97

## LABORERS CLASSIFICATIONS:

GROUP 1: Carloaders, choker setter, concrete crewman, crushed feeder, demolition laborers, including salvaging all material, loading, cleaning up, wrecking, dumpmen, flagmen, fence erector and installer (other than chain link), including installation and erection of fence, guard rails, medial rails, reference posts, guide posts and right-of-way markers, form strippers, general laborers, railroad track laborers, riprap man, scale man, stake jumper, structure mover, includes foundation, separation, preparation, cribbing, shoring, jacking and unloading of structures, water nozzleman, timber buckler and faller, truck loader, water boys, tool room men.

GROUP 2: Combined air and water nozzleman, cement handler, dope pot fireman (nonmechanical), form cleaning machine, mechanical railroad equipment (includes spiker, puller, tile cleaner, tamper, pipe wrapper, power driven wheelbarrows, operators of hand derricks, towmasters, scootcretes, buggymobiles and similar equipment), tamper or rammer operator, trestle scaffold builders over one tier high, power tool operator (gas, electric or pneumatic), sandblast or gunnite tailhose man, scaffold erector, (steel or wood), vibrator operator (up to 4 feet), asphalt cutter, mortar men, shorer and lagger, creosote material handler, corrosive enamel or equl, paver breaker and jackhammer operators.

GROUP 3: Multi-section pipe layer, non-metallic clay and concrete pipe layer (including caulker, collarman, jointer, rigger and jacker, thermal welder and corrugated metal culvert pipe layer.

GROUP 4: Asphalt block pneumatic cutter, asphalt roller, walker, chainsaw operator with attachment, concrete saw (walking), high scalers, jackhammer operator (using over 6 feet of steel), vibrator operator (4 feet and over), well point installer, air trac operator.

GROUP 5: Asphalt screeder, big drills, cut of the hole drills (1 1/2 " piston or larger), down the hole drills (3 1/2" piston or larger) gunnite or sandblaster nozzleman, asphalt raker, asphalt tamper, form setter, demolition torch operator, shotcrete nozzlemen and potman.

GROUP 6: Powderman, master form setters.

GROUP 7: Brick paver (asphalt block paver, asphalt block sawman, asphalt block grinder, hastings block or similar type)

GROUP 8: Licensed powdermen.

LABO0657-004 06/01/2010

	Rates	Fringes
Laborers: (HAZARDOUS WASTE REMOVAL, EXCEPT ON MECHANICAL SYSTEMS: Preparation for, removing and encapsulation of hazardous materials from non-mechanical systems)		
Skilled Asbestos Abatement Laborers.....	\$ 17.82	5.97
Skilled Toxic and Hazardous Waste Removal Laborers.....	\$ 20.97	5.97

LABO0657-005 06/01/2010

	Rates	Fringes
Laborers: (TUNNEL, RAISE & SHAFT (FREE AIR) FOR HEAVY AND SEWER & WATER LINES CONSTRUCTION)		
GROUP 1.....	\$ 22.41	5.97
GROUP 2.....	\$ 23.10	5.97
GROUP 3.....	\$ 24.85	5.97
GROUP 4.....	\$ 25.60	5.97

LABORERS CLASSIFICATIONS:

GROUP 1: Brakeman, Bull Gang, Dumper, Trackmen, Concrete Man.

GROUP 2: Chuck Tender, Powdermen in Prime House, Form Setters and Movers, Nippers, Cableman, Houseman, Groutman, Bell or Signalman, Top or Bottom Vibrator Operator.

GROUP 3: Miners, Re-Bar Underground, Concrete or Gunnite Nozzlemen, Powdermen, Timbermen and Re-Timbermen, Wood Steel Including Liner plate or Other Support, Material Motorman, Caulkers, Diamond Drill Operators, Riggers, Cement Finishers-Underground, Welders and Burners, Shield Driver, Air Trac Operator, Shotcrete Nozzlemen and Potman.

GROUP 4: Mucking Machine Operator (Air).

LABO0657-006 06/01/2010

	Rates	Fringes
Laborers: (TUNNEL, RAISE AND SHAFT (COMPRESSED AIR) FOR HEAVY CONSTRUCTION ONLY		
Gauge Pressure Work Period		
(Pounds)	(Hours)	
1-14	7.....	\$ 28.85
14-18	6.....	\$ 33.95

FOOTNOTE: On any requirement for air pressure in excess of 18 PSI, work periods and rates should be negotiated at a pre-bid conference.

LABO0657-007 06/01/2010

	Rates	Fringes
Laborers: (PAVING AND		

## INCIDENTAL GRADING)

Asphalt Raker & Concrete		
Saw Operator.....	\$ 18.42	4.90
Asphalt Shoveler.....	\$ 17.84	4.90
Asphalt Tammer & Concrete		
Shoveler.....	\$ 18.09	4.90
Jack Hammer.....	\$ 18.51	4.90
Laborer.....	\$ 17.70	4.90
Sand Setter & Form Setter...	\$ 19.10	4.90

LABO0657-008 06/01/2010

	Rates	Fringes
LABORERS (BRICK MASONRY WORK)		
Mason Tenders.....	\$ 15.32	5.97
Scaffold Builders, Mortarmen.....	\$ 16.20	5.97

\* MARB0002-003 05/01/2011

	Rates	Fringes
Marble & Stone Mason		
Includes Pointing, Caulking and Cleaning of All Types of Masonry, Brick, Stone and Cement Structures.....	\$ 32.88	13.99

MARB0003-001 05/01/2010

	Rates	Fringes
Mosaic & Terrazzo Worker, Tile Layer		
Marble Mason and Tile Layer..	\$ 25.29	9.59
Terrazzo Worker.....	\$ 26.04	9.59

MARB0003-004 05/01/2010

	Rates	Fringes
Marble, Tile & Terrazzo Finisher.....	\$ 20.48	8.44

PAIN0051-001 06/01/2010

	Rates	Fringes
Painters:		
All Industrial Work.....	\$ 27.68	7.86
Bridges, Heavy Highway, Lead Abatement and Flame/Thermal Spray.....	\$ 31.32	7.86
Commercial and Mold Remediation, Painters, Wallcovers and Drywall Finishers.....	\$ 24.64	7.86
Metal Polishing and Refinishing.....	\$ 25.64	7.86

PLAS0891-001 05/01/2010

	Rates	Fringes
Cement Masons:		
HEAVY CONSTRUCTION ONLY.....	\$ 27.15	9.58

PLAS0891-002 06/01/2007

	Rates	Fringes
Cement Masons: (PAVING & INCIDENTAL GRADING)		
Cement Masons.....	\$ 17.35	4.35
Concrete Saw Operators.....	\$ 17.35	4.35
Form Setters.....	\$ 17.35	4.35

PLUM0005-001 08/01/2010

	Rates	Fringes
Plumbers.....	\$ 37.67	14.69+a
a. PAID HOLIDAYS: Labor Day, Veterans' Day, Thanksgiving Day and the day after Thanksgiving, Christmas Day, New Year's Day, Martin Luther King's Birthday, Memorial Day and the Fourth of July.		

PLUM0602-005 11/01/2010

	Rates	Fringes
Steamfitter, Refrigeration & Air Conditioning Mechanic.....	\$ 36.87	16.72+a
a. PAID HOLIDAYS: New Year's Day, Martin Luther King's Birthday, Memorial Day, Independence Day, Labor Day, Veterans Day, Thanksgiving Day and the day after Thanksgiving and Christmas Day.		

SHEE0100-001 01/01/2011

	Rates	Fringes
Sheet Metal Worker.....	\$ 35.59	13.01

TEAM0639-001 06/01/2010

	Rates	Fringes
Truck drivers: (HEAVY & HIGHWAY CONSTRUCTION)		
Tractor trailer, Low Boy....	\$ 20.50	2.00+a
Truck Drivers.....	\$ 18.50	2.00+a
a. VACATION: Employees will receive one (1) week's paid vacation after one (1) year of service.		

TEAM0639-005 06/01/2009

	Rates	Fringes
Truck drivers: (PAVING & INCIDENTAL GRADING)		
All paving projects where the grading is incidental to the paving.....		
	\$ 18.00	4.00

WELDERS - Receive rate prescribed for craft performing operation to which welding is incidental.

Unlisted classifications needed for work not included within the scope of the classifications listed may be added after award only as provided in the labor standards contract clauses (29CFR 5.5 (a) (1) (ii)).

-----  
In the listing above, the "SU" designation means that rates listed under the identifier do not reflect collectively bargained wage and fringe benefit rates. Other designations indicate unions whose rates have been determined to be prevailing.  
-----

WAGE DETERMINATION APPEALS PROCESS

1.) Has there been an initial decision in the matter? This can be:

- \* an existing published wage determination
- \* a survey underlying a wage determination
- \* a Wage and Hour Division letter setting forth a position on a wage determination matter
- \* a conformance (additional classification and rate) ruling

On survey related matters, initial contact, including requests for summaries of surveys, should be with the Wage and Hour Regional Office for the area in which the survey was conducted because those Regional Offices have responsibility for the Davis-Bacon survey program. If the response from this initial contact is not satisfactory, then the process described in 2.) and 3.) should be followed.

With regard to any other matter not yet ripe for the formal process described here, initial contact should be with the Branch of Construction Wage Determinations. Write to:

Branch of Construction Wage Determinations  
Wage and Hour Division  
U.S. Department of Labor  
200 Constitution Avenue, N.W.  
Washington, DC 20210

2.) If the answer to the question in 1.) is yes, then an interested party (those affected by the action) can request review and reconsideration from the Wage and Hour Administrator (See 29 CFR Part 1.8 and 29 CFR Part 7). Write to:

Wage and Hour Administrator  
U.S. Department of Labor  
200 Constitution Avenue, N.W.  
Washington, DC 20210

The request should be accompanied by a full statement of the interested party's position and by any information (wage payment data, project description, area practice material, etc.) that the requestor considers relevant to the issue.

3.) If the decision of the Administrator is not favorable, an interested party may appeal directly to the Administrative Review Board (formerly the Wage Appeals Board). Write to:

Administrative Review Board  
U.S. Department of Labor  
200 Constitution Avenue, N.W.  
Washington, DC 20210

4.) All decisions by the Administrative Review Board are final.

=====  
END OF GENERAL DECISION