

<b>AMENDMENT OF SOLICITATION / MODIFICATION OF CONTRACT</b>			1. Contract Number	Page of Pages	
				1	7
2. Amendment/Modification Number	3. Effective Date	4. Requisition/Purchase Request No.	5. Solicitation Caption		
Amendment No. 4	See Box 16C		Safety Improvement on New Jersey, NW from N Street NW to H Street NW & Reconstruction of New York Avenue, NW from First NW to 4 <sup>th</sup> Street NW.		
6. Issued by:		Code	7. Administered by (If other than line 6)		
District Department of Transportation Office of Contracting and Procurement 55 M Street SE – 7 <sup>th</sup> Floor Washington, DC 20003			Infrastructure Project Management Division (IPMD) District Department of Transportation 55 M Street SE, Suite 400 Washington, DC 20003		
8. Name and Address of Contractor (No. street, city, county, state and zip code)		X	9A. Amendment of Solicitation No. DCKA-2018-B-0017		
TO ALL PROSPECTIVE OFFERORS			9B. Dated (See Item 11) August 28, 2018		
			10A. Modification of Contractor/Order No.		
			10B. Dated (See Item 13)		
Code	Facility				
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS					
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended. <input checked="" type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning one (1) copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) BY separate letter or fax which includes a reference to the solicitation and amendment number. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such may be made by letter or fax, provided each letter or telegram makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. Accounting and Appropriation Data (If Required)					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14					
A. This change order is issued pursuant to (Specify Authority): 27 DCMR, Chapter 36, Section 3601.2(b) The changes set forth in Item 14 are made in the contract/order no. in item 10A.					
B. The above numbered contract/order is modified to reflect the administrative changes (such as changes in paying office, appropriation data etc.) set forth in item 14, pursuant to the authority of:					
C. This supplemental agreement is entered into pursuant to authority of: 27 DCMR 3601.2 Change Clause, 27 DCMR 2005.6(d) as amended					
D. Other (Specify type of modification and authority) Paragraph 15, Changes, Standard Contract Provisions					
E. IMPORTANT: Contractor <input type="checkbox"/> is not <input checked="" type="checkbox"/> is required to sign this document and return one (1) copy to the issuing office.					
14. Description of Amendment/Modification (Organized by UCF Section headings, including solicitation/contract subject matter where feasible.)					
<p>Invitation No.: DCKA-2018-B-0017 (FAP No. 2017 (042) is hereby amended as follows:</p> <ol style="list-style-type: none"> <li>This amendment includes response to submitted questions.</li> <li>In (a) Bid Forms and Proposals Package delete and replace the Non-Collusion Affidavit with the revised Non-Collusion Affidavit document attached.</li> <li>Add the following 51. Non-Collusion Affidavit to the Invitation for Bid (IFB):</li> </ol> <p>Pursuant to 23 CFR 635.112(f), each bidder shall file a non-collusion statement certifying that the bidder has not, either directly or indirectly, entered into any agreement, participated in any collusion, or otherwise taken any action, in restraint of free competitive bidding in connection with the submitted bid. Failure to submit the executed statement as part of the bid will make the bid nonresponsive and ineligible for award.</p>					
Except as provided herein, all terms and conditions of the document is referenced in Item 9A or 10A remain unchanged and in full force and effect.					
15A. Name and Title of Signer (Type or print)		16A. Name of Contracting Officer			
		Margaret Platek Contracting Officer			
15B. Name of Contractor	15C. Date Signed	16B. District of Columbia		16C. Date Signed	
(Signature of person authorized to sign)		Margaret J. Wade (Signature of Contracting Officer)		28th Sept. 2018	

**CONTINUATION SHEET  
AMENDMENT OF SOLICITATION / MODIFICATION OF CONTRACT**

Amendment No. 4	Solicitation Number DCKA-2018-B-0017		Page of Pages
	Safety Improvement on New Jersey, NW from N Street NW to H Street NW & Reconstruction of New York Avenue, NW from First NW to 4 <sup>th</sup> Street NW.		2   7

4. In the Appendices to the solicitation delete and replace the Employee Training Requirements document with the attached revised Employee Training Requirements.

ID	Questions	Responses to Questions - Amendment 4
1	Will there be any removable tape used for the temporary striping during the various maintenance of traffic phases.	No, only temporary paint per plans, estimate, and 2013 standard specifications section 612.13
2	Phase 5 traffic control plans call for temporary preformed interstate shields. Will a bid item be added for these markings?	Per the 2013 standard specifications section 612.14, temporary preformed letters and arrows are included within the same preformed pavement markings bid item. Quantity for Item 612112 will be revised to include temporary shields.
3	Phase 5 traffic control plans call for temporary preformed letters and arrows. Will a bid item be added for these markings?	Per the 2013 standard specifications, temporary preformed letters and arrows are included within the same preformed pavement markings bid item. Quantities for Items 612068 & 612070 will be revised to include temporary arrows.
4	Pavement marking plans call for GREEN THERMOPLASTIC for some sections of the bicycle lanes. This type of marking on past projects has been completed using Ride-a-way green coating or similar product, not thermoplastic. Will these markings be thermoplastic or green paint product and will a bid item be added for this work.	Green markings should be a green colored two part epoxy paint. One part base epoxy paint and second part a FHWA #2 Bike Lane Green liquid tint (or approved equal). Bid item will be added for this.
5	There is no bid item for bicycle symbols. Will a bid item be added for these markings. Bid item no. 612112, which is erroneously noted as a LF marking rather than EACH does not have sufficient quantities to cover the number of bicycle symbols in the plans.	Bid item number 612112 is for the preformed interstate/state shields. Bid quantity type will be updated. Item 612076 Thermoplastic Bicycle Symbol (Each) will be added.
6	There is no bid item for permanent preformed interstate shields called for in the pavement marking plans. Will a bid item be added for these markings.	This is covered under bid item 612112
7	Pavement marking plans call for 2 component pavement markings on several concrete areas. Will a bid item be added for these markings. Pavement markings on concrete are generally placed using preformed contrast tape, not 2 component pavement markings.	Either product can be used. A separate bid item will be added for the 2 component pavement markings
8	Pavement marking plans call for preformed contrast pavement markings (bicycle symbols and directional arrows). Will bid items be added for these markings.	Bid item for high contrast bike symbol will be added. No bid item will be added for high contrast directional arrows. Pavement marking legend "T" is not actually used on the plans.

**CONTINUATION SHEET  
AMENDMENT OF SOLICITATION / MODIFICATION OF CONTRACT**

Amendment No. 4

Safety Improvement on New Jersey, NW from N Street NW to H Street NW & Reconstruction of New York Avenue, NW from First NW to 4<sup>th</sup> Street NW.

Solicitation Number  
DCKA-2018-B-0017

Page of Pages  
**3**

7

ID	Questions	Responses to Questions - Amendment 4
9	Pavement marking plans call for all letters and arrows to be preformed. These markings are normally placed using extruded thermoplastic, not preformed thermoplastic. Bid items call for thermoplastic and do not specify preformed.	Per 2013 Standard specifications arrows, symbols, and letters should be Permanent Preformed Thermoplastic per section 612.14.
10	Please specify the definition of work of line item 0495, item # 612999 Traffic Control Special Item.	This item was added by DDOT/Alpha for temporary construction signs on 6/30/2017
11	Please provide the scope of works for line number 0870 Removal of overhead Sign Structure,	This line item is for the removal of the overhead sign structure at Sta 314+20 along New Jersey Avenue, and the overhead sign structure at Sta 317+20 along New York Avenue. The full structure and foundation shall be removed according to DDOT specifications.
12	This job requires 2 bridge laborer trainees however there is no bridge work on this job. Can this be replaced with different trainee classification?	Updated Employee Training Requirements included in the Amendment No. 4
13	Line item 0125 refers to Gate Butterfly Valve 9 Inch. Is this just a typo error for 8 Inch gate valve? If so, please modify.	Valve is meant to be an 8" gate valve. Estimator catalog does not have an 8" valve so 9" is used as a substitute. Estimate has been updated to reflect this in the notes. See attached
14	Line item 0135, item # 306991 refers to Gate Butterfly Valve Special Item. Please let us know what is the size of this gate valve and whether the valve casing for this valve is part of this pay item.	Gate Butterfly Valve special item is used for Air Release valve. Notes have been added to clarify this and quantity updated.
15	Utility plan has proposed air release valve. What pay item covers this work? Eg. Note 17 on sheet 152.	See response to number 14

**CONTINUATION SHEET  
AMENDMENT OF SOLICITATION / MODIFICATION OF CONTRACT**

Amendment No. 4	Safety Improvement on New Jersey, NW from N Street NW to H Street NW & Reconstruction of New York Avenue, NW from First NW to 4 <sup>th</sup> Street NW.	Solicitation Number DCKA-2018-B-0017	Page of Pages 4 / 7
16	Please more information on item 0870 Remove Overhead structure and identify its location.	See response to number 11	
17	Line Number 0495 – 612999. Traffic Control Special Item – SF 1033 SF. There is no description for this item. Is this a pavement marking?	See response to number 10	

**INVITATION NO.** DCKA-2018-B-0017

**PROJECT NAME:** Safety Improvement on New Jersey, NW from N Street NW to H Street NW & Reconstruction of New York Avenue, NW from First to 4th Street NW.

**NON-COLLUSION AFFIDAVIT**

I, the undersigned depose and certify that I am the \_\_\_\_\_ Title of the \_\_\_\_\_ Company that I am authorized to make this affidavit on behalf of said company; and that said company has not, either directly or indirectly, entered into any agreement, participated in any collusion, or otherwise taken any action in restraint of free competitive proposal submittal in connection with proposed contract and pursuant to 23 CFR 635.112 (f).

---

Signature of Official

---

Date

**EMPLOYEE TRAINING REQUIREMENTS**

23 CFR, Part 230, Subpart A, Appendix B applies to this contract, except as modified below. Prior to commencing, the contractor shall submit to the DC Department of Transportation Contracting Officer for approval, the number of trainees to be trained in each selected and classification and providing the prospective trainee's home address(es) and social security number(s). The number of trainees to be trained under this contract is (4) shall be in the following classifications:

<b><u>CRAFT</u></b>	<b><u>NUMBER</u></b>
Cement Mason	2
Form Setter	2

The minimum length and type of training for each classification will be as established in the training program selected by the contractor and approved by the Contracting Officer, DC Department of Transportation and the Division Engineer, Federal Highway Administration.

For purposes of this requirement, a trainee is defined as a person who is registered and receiving on-the-job training in a construction or construction management occupation under a program which has been approved and certified in advance by the U.S. Department of Labor, Employment and Training Administration or by the Division Engineer, Federal Highway Administration.

A trainee differs from an apprentice in that an apprentice means (1) a person employed and individually registered in a bona fide apprenticeship program registered with the U.S. Department of Labor, Employment and Training Administration, Bureau of Apprenticeship and Training, or with a State Apprenticeship Agency recognized by the Bureau, or (2) a person in the first 90 days of probationary employment in an apprenticeship program, who is not individually registered in the program, but who has been certified by the Bureau of Apprenticeship and Training or a State Apprenticeship Agency (where applicable) to be eligible for probationary employment as an apprentice.

Contractors are encouraged to utilize the resources of the District of Columbia, Department of Employment Services, Employer Services Center and the District of Columbia, Department of Transportation to recruit and hire prospective trainees. Prospective trainees who are not enrolled in any approved program may be selected from among the contractor's construction workforce, subject to the approval of the Contracting Officer.

The District Department of Transportation-Construction Contract Branch will monitor your training program closely during the life of the project to ensure that the training program is being administered in compliance with the applicable Federal regulations and that the assigned number of trainees are enrolled and receiving

training. Contractors are reimbursed only for training actually given and carefully documented by the Project Engineer and verified by the District Department of Transportation-Construction Contract Branch.

**APPRENTICESHIP PROGRAM:**

All prime Contractors and subcontractors who contract with the District of Columbia Government to perform construction or renovation work with a single contract or cumulative contracts of at least \$500,000.00, let within a twelve (12) month period, shall be required to register an apprenticeship program with the District of Columbia Apprenticeship Council. (D.C. Code 36-409((1981))).

**APPRENTICES AND TRAINEES:**

This S.P. supplements APPRENTICES AND TRAINEES, ARTICLE 3 of STANDARD CONTRACT PROVISIONS FOR USE WITH SPECIFICATIONS FOR DISTRICT GOVERNMENT CONSTRUCTION PROJECTS, DATED 1973; as amended by the Transmittal Sheet No. 5.

- (1) In Items A, B and C, except for subparagraph C5, wherever the words "Apprenticeship Council, D.C. Department of Labor" appear, add immediately after: "and/or U.S. Department of Labor."
- (2) In Item B. Trainees, add the following: "Training programs approved under the requirements of Article IV; Section 4 and 5 of Required Contract Provisions, Federal Aid Construction Contracts (Form FHWA-1273) will satisfy the requirements of this item.

The contractor and all subcontractors shall furnish to the Contracting Officer written evidence of the registration of his/her program and apprentices as well as the appropriate ratios and wage rates for the areas of construction, prior to using any apprentice on the contract.