


<b>AMENDMENT OF SOLICITATION / MODIFICATION OF CONTRACT</b>			1. Contract Number DCKT-2009-B-0063	Page of Pages 1   3
2. Amendment/Modification Number DCKT-2009-B-0063-0003	3. Effective Date 5/28/09	4. Requisition/Purchase Request No.	5. Solicitation Caption Remove existing fuel tanks	
6. Issued by: Office of Contracting and Procurement 2000 14 <sup>th</sup> Street, N.W. 6 <sup>th</sup> Floor Washington, D.C. 20009		Code	7. Administered by (If other than line 6)	
8. Name and Address of Contractor (No. street, city, county, state and zip code)		9A. Amendment of Solicitation DCKT-2009-B-0063		
Code		9B. Dated (See Item 11)		
Facility		10A. Modification of Contract Order No. DCKT-2009-B-0063		
		10B. Dated (See Item 13) 5/27/09		
<b>11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS</b>				
<input type="checkbox"/> The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended. <input checked="" type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) BY separate letter or fax which includes a reference to the solicitation and amendment number. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such may be made by letter or fax, provided each letter or telegram makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
12. Accounting and Appropriation Data (If Required)				
<b>13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14</b>				
A. This change order is issued pursuant to (Specify Authority): The changes set forth in Item 14 are made in the contract/order no. in item 10A.				
B. The above numbered contract/order is modified to reflect the administrative changes (such as changes in paying office, appropriation data etc.) set forth in item 14, pursuant to the authority of 27 DCMR, Chapter 36, Section 3601.2.				
C. This supplemental agreement is entered into pursuant to authority of:				
D. Other (Specify type of modification and authority)				
<b>E. IMPORTANT:</b> Contractor <input type="checkbox"/> is not <input checked="" type="checkbox"/> is required to sign this document and return <u>1</u> copies to the issuing office.				
14. Description of Amendment/Modification (Organized by UCF Section headings, including solicitation/contract subject matter where feasible.)				
See answers to questions per pre-bid conference.				
Except as provided herein, all terms and conditions of the document referenced in item (9A or 10A) remain unchanged and in full force and effect.				
15A. Name and Title of Signer (Type or print)		16A. Name of Contracting Officer Gena Johnson		
15B. Name of Contractor  (Signature)	15C. Date Signed	16B. District of Columbia  (Signature of Contracting Officer)	16C. Date Signed 5/28/09	

<b>AMENDMENT OF SOLICITATION / MODIFICATION OF CONTRACT</b>			1. Contract Number	Page of Pages
				2   3
2. Amendment/Modification Number	3. Effective Date	4. Requisition/Purchase Request No.	5. Solicitation Caption	
DCKT-2009-B-0063-0003	5/27/09		Remove existing fuel tanks	

**ANSWERS TO SOLICITATION QUESTIONS**

**ALL LOCATIONS:**

- All canopies must have a height of 13' and a minimum area of 600 sf.
- The submersible pump, piping, and conduit used at all locations shall meet or exceed the minimum required by any and all applicable codes, laws, and manufacturer specifications.
- No assumptions shall be made on the reuse of any piping, conduit, or material unless otherwise specified in the scope of work.
- Yes CLIN No.9 and only CLIN No.9 in section C.1.10 and C.1.11 does require the component upgrade for the E.J. Ward Terminal along with the stainless steel cabinet.
- There are no reliable drawings available for any of the facilities; therefore no drawings shall be used for this bid package.
- All dispenser sumps shall be in conformance with all applicable codes, regulations, and manufacturer's specifications.
- All existing wiring shall be deemed insufficient and new wiring shall be included in the bid pricing.
- The 400w lighting for the canopies is assumed to be four 400w bulbs in exterior fixtures.
- Oak Hill's diesel tanks are the only tanks to be removed and they will be replaced with one 2000 gallon AST. All associated fill, compaction, and repair shall be included in the bid.

**OAK HILL:**

- The Kiosk at Oak Hill shall be a minimum of 80 sf.
- The Kiosk shall be located on the grass area in the vicinity of the new above ground tank.
- Power for the Kiosk will be run from the existing garage.
- The dispensers at Oak Hill shall be:
  - Unleaded
    - Replace the existing with digital gas boy stainless steel dual hose dispensers
  - Diesel
    - Replace the existing with a dual hose gas boy stainless steel to be connected to the new above ground tank.
- The new piping from the new above ground diesel tank shall be above ground where possible.
- This location shall receive two new canopies.
  - One for unleaded
  - One for diesel
- The garage is located on the opposite side of the dispensers as the warehouse. Conduit and wiring shall run from the garage to the new kiosk to power the existing unleaded tank, and the new kiosk to power the existing unleaded tank, and the new 2000 gallon above ground diesel that replaces the existing three diesel tanks.

**V STREET:**

- V Street shall include two canopies
  - One unleaded
  - One diesel
  - The diesel canopy will not require an additional permit.
  - The existing lighting electrical supply next to the proposed diesel canopy shall be assumed sufficient for the canopy new lights.

<b>AMENDMENT OF SOLICITATION / MODIFICATION OF CONTRACT</b>		1. Contract Number	Page of Pages
			3   3
2. Amendment/Modification Number	3. Effective Date	4. Requisition/Purchase Request No.	5. Solicitation Caption
DCKT-2009-B-0063-0003	5/27/09		Remove existing fuel tanks

**ADAMS PLACE:**

- The scope of work for Adams place does not require the fuel tank to be removed.
- Any concrete or asphalt disturbed shall be replaced in kind or better.
- Adams Place shall receive one canopy with four lights.

**West Virginia Ave:**

- West Virginia Ave shall have two new canopies. One for the E-85, and one for the new CNG dispenser, each containing four lights.