

2. Amendment/Modification Number DCKT-2010-B-0171-001	3. Effective Date SEE 16C BELOW	4. Requisition/Purchase Request No.	5. Solicitation Caption: REPLACEMENT OF THE BENNING ROAD ROOF
---	---	-------------------------------------	---

6. Issued by: Office of Contracting and Procurement Transportation & Specialty Equipment Commodity Group 2000 14 th Street, N.W., 6 th Floor Washington, DC 20009	Code KT0	7. Administered by (If other than line 6) Office of Contracting and Procurement Transportation & Specialty Equipment Commodity Group 2000 14 th Street, N.W., 6 th Floor Washington, DC 20009
---	-----------------	---

8. Name and Address of Contractor (No. street, city, county, state and zip code)	X	9A. Amendment of Solicitation DCKT-2010-B-0171
		9B. Dated (See Item 11) 6/21/10
		10A. Modification of Contract Order No.
		10B. Dated (See Item 13)

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers is extended. is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) BY separate letter or fax which includes a reference to the solicitation and amendment number. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such may be made by letter or fax, provided each letter or telegram makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. Accounting and Appropriation Data (If Required)

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTORS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14

	A. This change order is issued pursuant to (Specify Authority): The changes set forth in Item 14 are made in the contract/order no. in item 10A.
	B. The above numbered contract/order is modified to reflect the administrative changes (such as changes in paying office, appropriation data etc.) set forth in item 14, pursuant to the authority of 27 DCMR, Chapter 36, Section 3601.2.
	C. This supplemental agreement is entered into pursuant to authority of:
	D. Other (Specify type of modification and authority)


E. IMPORTANT: Contractor is not is required to sign this document and return 1 copies to the issuing office.

14. Description of Amendment/Modification (Organized by UCF Section headings, including solicitation/contract subject matter where feasible.)

Responses to Bidders' Questions are provided on Page 2.

This amendment, together with your bid, must be received by the District no later than the date and time set for bid submission. Revisions or price changes occasioned by this amendment must be received by the District no later than the date and time set for bid submission. **Failure to acknowledge receipt of this Amendment, Number 1, for Solicitation number: DCKT-2010-B-0171, Replacement of the Benning Road Roof, may be cause for rejection of any bid submitted in response to the subject solicitation.**

Except as provided herein, all terms and conditions of the document referenced in item (9A or 10A) remain unchanged and in full force and effect.

15A. Name and Title of Signer (Type or print)	16A. Name of Contracting Officer Gena Johnson		
15B. Name of Contractor (Signature)	15C. Date Signed	16B. District of Columbia 	16C. Date Signed 7/16/10

AMENDMENT OF SOLICITATION / MODIFICATION OF CONTRACT			1. Contract Number	Page of Pages
2. Amendment/Modification Number	3. Effective Date	4. Requisition/Purchase Request No.	5. Solicitation Caption	2 2
DCKT-2010-B-0171-001	SEE 16C		REPLACEMENT OF THE BENNING ROAD ROOF	

RESPONSE TO BIDDER'S QUESTIONS

1. What kind of roofing system does it require?

A built up roofing system.

2. What is the range of total project value?

\$500,000.00 to \$1,000,000.00 (Refer to section B.2 of the solicitation)

3. Is a bid bond required?

Yes, 5%. (Refer to Section L.15 of the solicitation)

4. Is a digital copy of the drawings available?

No.

5. What is the green roof dead load?

Specification Section 077100 Roof Specialties, Part 5 Paragraph 5.1.D.1

Replace: "Extensive System (4 inch) 18-22 lbs per sf" with
"Ultra Extensive Modules (2.5 inch deep) Approx. 11-13 lbs per sf"