

<b>AMENDMENT OF SOLICITATION / MODIFICATION OF CONTRACT</b>			1. Contract Number	Page of Pages 1   2
2. Amendment/Modification Number DCKT-2010-B-0224-002	3. Effective Date August 25, 2010	4. Requisition/Purchase Request No.	5. Solicitation Caption Above Ground Fuel Tank	
6. Issued by: Office of Contracting and Procurement Transportation and Specialty Equipment Commodity Group 2000 14 <sup>th</sup> Street, NW, 6 <sup>th</sup> Floor Washington, DC 20001		Code	7. Administered by (If other than line 6)	
8. Name and Address of Contractor (No. street, city, county, state and zip code)		X	9A. Amendment of Solicitation DCKT-2010-B-0224	
			9B. Dated (See Item 11) 8/16/10	
			10A. Modification of Contract Order No.	
			10B. Dated (See Item 13)	
Code	Facility	11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS		
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended. <input checked="" type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) BY separate letter or fax which includes a reference to the solicitation and amendment number. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such may be made by letter or fax, provided each letter or telegram makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
12. Accounting and Appropriation Data (If Required)				
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTORS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14				
A. This change order is issued pursuant to (Specify Authority): The changes set forth in Item 14 are made in the contract/order no. in item 10A.				
B. The above numbered contract/order is modified to reflect the administrative changes (such as changes in paying office, appropriation data etc.) set forth in item 14, pursuant to the authority of 27 DCMR, Chapter 36, Section 3601.2.				
C. This supplemental agreement is entered into pursuant to authority of:				
D. Other (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not <input checked="" type="checkbox"/> is required to sign this document and return <u>1</u> copies to the issuing office.				
14. Description of Amendment/Modification (Organized by UCF Section headings, including solicitation/contract subject matter where feasible.) Solicitation DCKT-2010-B-0224 is hereby amended as follows: A. Responses to bidders questions are provided on page 2. B. As discussed during the site visit on August 20, 2010, the requirements will include a veeder-root monitoring system and kiosk. The location of the tank will be the parking lot between the two light poles shown in the attached picture. The dispensers will be located such that a bus can fill up on either side of the tank. The power source is located at the back of the trailers shown in the right side of the picture. The District is looking for a tank similar to that currently located at its 5 <sup>th</sup> and V St, NE location. C. Section C.3.21 is revised to read as follows: <b>C.3.21</b> The Contractor shall furnish and install a key reader fuel management system with surge protection, network card and modem. The fuel management systems shall be manufactured the EJ Ward system and shall match the existing system used by the District's Fleet Management System. The Contractor shall provide a start up and training session for the staff on the use, troubleshooting and operation of the system.				
Except as provided herein, all terms and conditions of the document referenced in item (9A or 10A) remain unchanged and in full force and effect.				
15A. Name and Title of Signer (Type or print)		16A. Name of Contracting Officer <i>Gena Johnson</i>		
15B. Name of Contractor  (Signature)		15C. Date Signed	16B. District of Columbia <i>[Signature]</i> (Signature of Contracting Officer)	16C. Date Signed 8/25/10

<b>AMENDMENT OF SOLICITATION / MODIFICATION OF CONTRACT</b>			1. Contract Number	Page of Pages
				2   2
2. Amendment/Modification Number	3. Effective Date	4. Requisition/Purchase Request No.	5. Solicitation Caption	
DCKT-2010-B-0224-002	August 25, 2010		Above Ground Fuel Tank	

Responses to Questions:

- A. Regarding C.1 Scope - Calls for two (2) dispensers with two (2) hoses each.
  - 1. What brand and model? **Digital gas boy electronic stainless steel dual hose dispensers**
  - 2. Product filter, internal or external and what micron? **Canister filter, Internal, 30 microns**
  - 3. Length of hose? **23/24 ft**
  
- B. Regarding C.3.21 -
  - 1. Will new keys be required and how many? **District will handle internally**
  - 2. Who will provide phone lines for modem? **District will handle internally**
  
- C. Regarding C.3.4 - Calls for two (2) dispenser/pumps
  - 1. If dispensers are used, what horse power will be required for the submerge turbine? **.75 hsp**
  - 2. Will the pumps or dispensers be allowed to be attached to the tank? **Yes, Installed on bravo box**
  - 3. Will the pumps or dispensers be set on dispenser sumps or above ground pans? **Above ground**
  
- D. Regarding C.3.12 -
  - 1. Manual or Electronic Monitoring? **Electronic**
  
- E. Regarding C.3.14 -
  - 1. Manual or electronic or both? **Electronic**
  
- F. What type and model veeder-root monitoring system? **TLS-450 with modem and Network card (1-8 are standard)**
  - a) Leak detection
  - b) CSLD
  - c) 3.0 test option
  - d) overfill with alarm
  - e) high/low monitoring
  - f) water float
  - g) Printer
  - h) Sump/pan filters
  - i) **Email notification**
  
- G. What size kiosk will be needed? **5 X 10**
- H. Will kiosk need to be heated and air conditioned? **Yes**
- I. Interior lights – how many? **Single light, double bulb**
- J. How many doors? **One door**
- K. Will door need tempered glass? **Yes – Additionally, windows to Kiosk need to be tinted**
- L. Size of panel electric box and voltage? **240-volt circuit**
- M. Concrete pad or metal frame? **Concrete**