

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. Contract Number	Page of Pages	
2. Amendment/Modification Number GF-2010-B-0006-005		3. Effective Date 12-May-10	4. Requisition/Purchase Request No.	5. Solicitation Caption See Caption below	1 2
6. Issued By: Univeristy of the District of Columbia Capital Procurement Division 4200 Connecticut Avenue, NW Washington, DC 20008		Code	7. Administered By (If other than line 6) Univeristy of the District of Columbia Capital Procurement Division 4200 Connecticut Avenue, NW Washington, DC 20008		
8. Name and Address of Contractor (No. Street, city, country, state and ZIP Code)			(X)	9A. Amendment of Solicitation No. GF-2010-B-0006	
				9B. Dated (See Item 11) 13-Apr-10	
				10A. Modification of Contract/Order No.	
				10B. Dated (See Item 13)	
Code		Facility			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS					
<input type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended. <input checked="" type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or fax which includes a reference to the solicitation and amendment number. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or fax, provided each letter or telegram makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. Accounting and Appropriation Data (If Required)					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14					
A. This change order is issued pursuant to: (Specify Authority) The changes set forth in Item 14 are made in the contract/order no. in item 10A.					
B. The above numbered contract/order is modified to reflect the administrative changes (such as changes in paying office, appropriation date, etc.) set forth in item 14, pursuant to the authority of 27 DCMR, Chapter 36, Section 3601.2.					
C. This supplemental agreement is entered into pursuant to authority of:					
D. Other (Specify type of modification and authority)					
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input checked="" type="checkbox"/> is required to sign this document and return _____ copies to the issuing office					
14. Description of amendment/modification (Organized by UCF Section headings, including solicitation/contract subject matter where feasible.) Solicitation No. GF-2010-B-0006, Renovation of Plaza Deck and Parking Garage is hereby amended as follows: (1). Questions and Answers (Attachment A) (2). All other terms and conditions remain the same.					
Except as provided herein, all terms and conditions of the document referenced in Item (9A or 10A) remain unchanged and in full force and effect					
15A. Name and Title of Signer (Type or print)			16A. Name of Contracting Officer Sherry Jones-Quashie		
15B. Name of Contractor		15C. Date Signed	16B. District of Columbia <i>Sherry Jones-Quashie</i>		16C. Date Signed 5/12/10
(Signature of person authorized to sign)			(Signature of Contracting Officer)		

ANSWERS TO OFFERORS QUESTIONS

Quest. No.	Question	Answer
1.	<p>We are in receipt of amendment 4 of the above referenced project. I sent you an earlier e-mail with regards to the quantity of concrete repair in the garage area not being able to be determined prior to the bid. Additionally, I would like to point out that on "Plaza Level Joint Repair Note" 5 of sheet S-5 (107 of 109) it states that "the engineer will be the sole judge of the extent and total quantity of repairs". Is it possible for the owner or engineer to state a quantity of each type of repair to be assumed for the bid. It is industry standard for this method of procurement to be implemented with a unit price quoted for over or under runs.</p> <p>Please advise as to what quantities should be assumed for the bid. Thank you in advance for any assistance you may be able to provide.</p>	<p>Type 1 Repair – 800 sq. yards Type 2 Repair – 400 sq yards Type 3 Repair – 100 linear feet</p>
2.	<p>In reference to question No. 18 of Amendment 4, the amount of delaminated concrete cannot be quantified by visual inspection. A sounding survey (for a building this size, about a 2 day process for a 2 man crew) must be performed to determine the extent of deterioration, nor can the depth (type 1 vs. type 2) be determined until demolition is actually performed. Please advise what quantity of each type of repair should be assumed if it is a lump sum bid.</p>	<p>Type 1 Repair – 800 sq. yards Type 2 Repair – 400 sq yards Type 3 Repair – 100 linear feet</p>