

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>			1. Contract Number	Page of Pages 1   2	
2. Amendment/Modification Number  RFQ730771-001	3. Effective Date  April 7, 2011	4. Requisition/Purchase Request No.	5. Solicitation Caption  Takoma Pool Chiller Replacement		
6. Issued By:  Department of Real Estate Services Contracting and Procurement Division 2000 14th Street, NW, Fifth Floor Washington, DC 20009		Code	7. Administered By (If other than line 6)  Department of Parks and Recreation 1480 Girard Street, NW Suite 420 Washington, DC 20009		
8. Name and Address of Contractor (No. Street, city, country, state and ZIP Code)			9A. Amendment of Solicitation No. RFQ 730771		
			X 9B. Dated (See Item 11)		
			10A. Modification of Contract/Order No.		
			10B. Dated (See Item 13)		
Code	Facility				
<b>11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS</b>					
<input type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input checked="" type="checkbox"/> is extended. <input type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or fax which includes a reference to the solicitation and amendment number. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or fax, provided each letter or telegram makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. Accounting and Appropriation Data (If Required)					
<b>13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14</b>					
A. This change order is issued pursuant to: (Specify Authority)					
The changes set forth in Item 14 are made in the contract/order no. in item 10A.					
B. The above numbered contract/order is modified to reflect the administrative changes (such as changes in paying office, appropriation date, etc.) set forth in item 14, pursuant to the authority of 27 DCMR, Chapter 36, Section 3601.2.					
C. This supplemental agreement is entered into pursuant to authority of:					
D. Other (Specify type of modification and authority)					
<b>E. IMPORTANT:</b> Contractor <input checked="" type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copy to the issuing office.					
14. Description of amendment/modification (Organized by UCF Section headings, including solicitation/contract subject matter where feasible.) The Subject Request for Quotation is hereby amended as follows:					
1. The due date for submission of quotes is hereby changed from 04/08/11 to 04/11/11 by 4:00 PM					
2. Amendment 1 - Attachment A - Site visit sign in sheet.					
3. Amendment 1 - Attachment B - Questions and answers.					
4. All other terms and conditions remain the same.					
15A. Name and Title of Signer (Type or print)			16A. Name of Contracting Officer Diane Wooden		
15B. Name of Contractor		15C. Date Signed	16B. District of Columbia 	16C. Date Signed 4-7-11	
(Signature of person authorized to sign)			Signature of Deputy Director, DRES, C&P Division		

<u>Name</u>	<u>Phone</u>	<u>Email</u>
Adebanjo Ojuri	202-545-0127	banjo.Ojuri@gsideworld.com
L Lawrence Burth	202 7013468	Cgphillips@k.com
John Peake		
Rickey Griffin	240 821 7236	Rick@specifieds.com
Anthony Best	202-529-1058	AHJordan_Plumbing@verizon.net
Mike Dent	202-723-0676	miked@wlgary.com
K Kane	202-391-7152	KKANGAAMS@AOL.COM
Perry Huger	202-636-1041	HugerHugerAir@AOL.COM

Corey Morgan  
 D.C. Parks & Rec.  
 Capital Construction  
 4/15/11

ATTACHMENT B  
RFQ730771  
Questions and Answers

Q-1. Should the price include new isolation valves, thermometers and pressure gages in the new connection to the new chiller?

A. Yes, the quote should include the above listed items.

Q-2. The existing piping connections are heat taped and insulated; should the price include extending the heat tape and insulation to the new chiller connection, and match the insulation thickness and provide the aluminum jacket. New piping connections on the Trane chiller differ from the current connections and will require additional piping.

A. Yes.

Q-3. Should water balancing of the new chiller be included?

A. Yes.

NOTE: Installation of connections and piping to the new chiller should follow best management practices and manufacturer specifications.